




# PROBLEM SUMMARY

## Sample Rating Trend






WATER



Machine Id  
**700990**  
 Component  
**Natural Gas Engine**  
 Fluid  
**IRVING 15W40 (--- GAL)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you check for the source of the coolant leak. Check for low coolant level. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	---
Iron	ppm	ASTM D5185m	>50	▲ 77	20	---
Sodium	ppm	ASTM D5185m	>101	▲ 167	3	---
Water	%	ASTM D6304	>0.1	▲ 2.41	---	---
ppm Water	ppm	ASTM D6304	>1000	▲ 24100	---	---
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG	---

Customer Id: GFL007  
 Sample No.: GFL0123441  
 Lab Number: 06215584  
 Test Package: FLEET



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Glycol Access	---	---	?	We advise that you check for the source of the coolant leak.

## HISTORICAL DIAGNOSIS

NORMAL



### 09 Dec 2020 Diag: Bill Quesnel

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id  
**700990**  
 Component  
**Natural Gas Engine**  
 Fluid  
**IRVING 15W40 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you check for the source of the coolant leak. Check for low coolant level. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

### ▲ Wear

Cylinder, crank, or cam shaft wear is indicated.

### ▲ Contamination

Sodium and/or potassium levels are high. There is a high concentration of water present in the oil.

### ▲ Fluid Condition

The oil is no longer serviceable due to the presence of contaminants.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>GFL0123441</b>	GFL0011110	---
Sample Date	Client Info		<b>10 Jun 2024</b>	09 Dec 2020	---
Machine Age	hrs	Client Info	<b>0</b>	8673	---
Oil Age	hrs	Client Info	<b>250</b>	1200	---
Oil Changed	Client Info		<b>Changed</b>	Changed	---
Sample Status			<b>SEVERE</b>	NORMAL	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>▲ 77</b>	20	---
Chromium	ppm	ASTM D5185m >4	<b>3</b>	1	---
Nickel	ppm	ASTM D5185m >2	<b>2</b>	<1	---
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	---
Silver	ppm	ASTM D5185m >3	<b>&lt;1</b>	<1	---
Aluminum	ppm	ASTM D5185m >9	<b>4</b>	2	---
Lead	ppm	ASTM D5185m >30	<b>16</b>	5	---
Copper	ppm	ASTM D5185m >35	<b>6</b>	6	---
Tin	ppm	ASTM D5185m >4	<b>3</b>	<1	---
Antimony	ppm	ASTM D5185m	<b>---</b>	0	---
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Beryllium	ppm	ASTM D5185m	<b>---</b>	0	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>64</b>	38	---
Barium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Molybdenum	ppm	ASTM D5185m	<b>30</b>	52	---
Manganese	ppm	ASTM D5185m	<b>4</b>	1	---
Magnesium	ppm	ASTM D5185m	<b>224</b>	32	---
Calcium	ppm	ASTM D5185m	<b>1982</b>	1882	---
Phosphorus	ppm	ASTM D5185m	<b>932</b>	737	---
Zinc	ppm	ASTM D5185m	<b>1166</b>	944	---
Sulfur	ppm	ASTM D5185m	<b>3154</b>	2169	---
Lithium	ppm	ASTM D5185m	<b>---</b>	<1	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	<b>21</b>	8	---
Sodium	ppm	ASTM D5185m >101	<b>▲ 167</b>	3	---
Potassium	ppm	ASTM D5185m >20	<b>7</b>	<1	---
Water	%	ASTM D6304 >0.1	<b>▲ 2.41</b>	---	---
ppm Water	ppm	ASTM D6304 >1000	<b>▲ 24100</b>	---	---

## INFRA-RED






	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	0	---
Nitration	Abs/cm	*ASTM D7624 >20	<b>16.2</b>	10.3	---
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>12.5</b>	23.1	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>13.5</b>	13.9	---
Base Number (BN)	mg KOH/g	ASTM D2896	<b>21.6</b>	---	---







# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	VLITE	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	● MILKY	NORML	---
Odor	scalar	*Visual	NORML	● NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG	---
Free Water	scalar	*Visual		● NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.1	13.7	---

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : GFL0123441  
**Lab Number** : 06215584  
**Unique Number** : 11088448  
**Test Package** : FLEET ( Additional Tests: Glycol, KF )

**Received** : 20 Jun 2024  
**Tested** : 24 Jun 2024  
**Diagnosed** : 24 Jun 2024 - Jonathan Hester

**GFL Environmental - 007 - Brunswick**  
 2809 Galloway Road  
 Bolivia, NC  
 US 28422  
 Contact: DONALD CRAVEN  
 dcraven@gflenv.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (910)253-4179