


## **OIL ANALYSIS REPORT**

Sample Rating Trend



Area (43480UA) Machine Id 834028 Component Natural Gas Engli Filid DIESEL ENGINE

834028 Component Natural Gas Engine Fluid

### DIESEL ENGINE OIL SAE 40 (--- GAL)

### DIAGNOSIS Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.


SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0122009	GFL0116552	GFL0122045
Sample Date		Client Info		25 Jun 2024	10 Jun 2024	17 May 2024
Machine Age	hrs	Client Info		1523	1411	1255
Oil Age	hrs	Client Info		1367	156	947
Oil Changed		Client Info		Changed	Not Changd	Changed
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	14	11	49
Chromium	ppm	ASTM D5185m	>4	<1	<1	1
Nickel	ppm	ASTM D5185m	>2	<1	0	1
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>3	0	0	<1
Aluminum	ppm	ASTM D5185m	>9	5	2	3
Lead	ppm	ASTM D5185m	>30	<1	<1	4
Copper	ppm	ASTM D5185m	>35	2	2	14
Tin	ppm	ASTM D5185m	>4	<1	<1	2
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	250	17	24	4
Boron Barium	ppm ppm	ASTM D5185m ASTM D5185m	250 10	17 <1	24 0	4 3
Boron Barium Molybdenum	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	250	17 <1 58	24 0 52	4 3 59
Boron Barium Molybdenum Manganese	ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100	17 <1 58 2	24 0 52 2	4 3 59 12
Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450	17 <1 58 2 701	24 0 52 2 626	4 3 59 12 832
Boron Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000	17 <1 58 2 701 1857	24 0 52 2 626 1762	4 3 59 12 832 1500
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150	17 <1 58 2 701 1857 974	24 0 52 2 626 1762 852	4 3 59 12 832 1500 785
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350	17 <1 58 2 701 1857 974 1171	24 0 52 2 626 1762 852 1011	4 3 59 12 832 1500 785 1000
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250	17 <1 58 2 701 1857 974 1171 3230	24 0 52 2 626 1762 852 1011 3062	4 3 59 12 832 1500 785 1000 2719
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 limit/base	17 <1 58 2 701 1857 974 1171 3230 current	24 0 52 2 626 1762 852 1011 3062 history1	4 3 59 12 832 1500 785 1000 2719 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon	ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m <b>method</b>	250 10 100 450 3000 1150 1350 4250 <i>limit/base</i> >+100	17 <1 58 2 701 1857 974 1171 3230 current 7	24 0 52 2 626 1762 852 1011 3062 history1 5	4 3 59 12 832 1500 785 1000 2719 history2 23
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 <b>limit/base</b> >+100 >216	17 <1 58 2 701 1857 974 1171 3230 current 7 10	24 0 52 2 626 1762 852 1011 3062 history1 5 5	4 3 59 12 832 1500 785 1000 2719 history2 23 5
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 <b>limit/base</b> >+100 >216 >20	17 <1 58 2 701 1857 974 1171 3230 current 7 10 6	24 0 52 2 626 1762 852 1011 3062 history1 5 5 5 3	4 3 59 12 832 1500 785 1000 2719 history2 23 5 2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 <b>limit/base</b> >+100 >216	17 <1 58 2 701 1857 974 1171 3230 current 7 10 6	24 0 52 2 626 1762 852 1011 3062 history1 5 5 3 3	4 3 59 12 832 1500 785 1000 2719 history2 23 5 2 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot %	ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 <b>limit/base</b> >+100 >216 >20 <b>limit/base</b>	17 <1 58 2 701 1857 974 1171 3230 current 7 10 6 current 0	24 0 52 2 626 1762 852 1011 3062 history1 5 5 5 3 3 history1 0	4 3 59 12 832 1500 785 1000 2719 history2 23 5 2 history2 0.1
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm ppm ppm ppm ppm TS ppm ppm ppm	ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 <b>limit/base</b> >216 >20 <b>limit/base</b>	17 <1 58 2 701 1857 974 1171 3230 current 7 10 6 current 0 9.9	24 0 52 2 626 1762 852 1011 3062 history1 5 5 5 3 history1 0 8.7	4 3 59 12 832 1500 785 1000 2719 history2 23 5 2 history2 0.1 13.0
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 <b>limit/base</b> >216 >20 <b>limit/base</b>	17 <1 58 2 701 1857 974 1171 3230 current 7 10 6 current 0	24 0 52 2 626 1762 852 1011 3062 history1 5 5 5 3 3 history1 0	4 3 59 12 832 1500 785 1000 2719 history2 23 5 2 2 history2 0.1
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 <b>limit/base</b> >216 >20 <b>limit/base</b>	17 <1 58 2 701 1857 974 1171 3230 current 7 10 6 current 0 9.9 20.0	24 0 52 2 626 1762 852 1011 3062 history1 5 5 3 history1 0 8.7 19.8 history1	4 3 59 12 832 1500 785 1000 2719 history2 23 5 2 history2 0.1 13.0 25.5 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 <b>limit/base</b> >216 >20 <b>limit/base</b> >20 >30 <b>limit/base</b>	17 <1 58 2 701 1857 974 1171 3230 current 7 10 6 current 0 9.9 20.0	24 0 52 2 626 1762 852 1011 3062 history1 5 5 5 3 3 history1 0 8.7 19.8	4 3 59 12 832 1500 785 1000 2719 history2 23 5 2 history2 0.1 13.0 25.5



Jan19/24 Feb 9/24 eb29/24

# **OIL ANALYSIS REPORT**






Mar21/24 kpr16/24 May3/24 .

/lav17/24

un10/24

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	14.8	14.8	14.5
GRAPHS						



Report Id: GFL652 [WUSCAR] 06222172 (Generated: 06/29/2024 10:52:38) Rev: 1

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate 12367

Submitted By: TECHNICIAN ACCOUNT

T:

F: