

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

433014 Component Natural Gas Engine Fluid PETRO CANADA DURON SHP 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0121750	GFL0106932	GFL0084631
Sample Date		Client Info		25 Jun 2024	03 Apr 2024	22 Nov 2023
Machine Age	hrs	Client Info		2727	2183	1834
Oil Age	hrs	Client Info		600	600	600
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	9	16	11
Chromium	ppm	ASTM D5185m	>4	<1	2	1
Nickel	ppm	ASTM D5185m	>2	<1	1	<1
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m		6	6	6
Lead	ppm	ASTM D5185m	>30	1	2	2
Copper	ppm	ASTM D5185m	>35	1	2	2
Tin	ppm	ASTM D5185m	>4	<1	2	1
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	12	8	6
Barium	ppm	ASTM D5185m	0	0	<1	0
Molybdenum	ppm	ASTM D5185m	60	54	54	55
Manganese	ppm	ASTM D5185m	0	<1	2	1
Magnesium	ppm	ASTM D5185m	1010	620	565	579
Calcium	ppm	ASTM D5185m	1070	1704	1616	1706
Phosphorus	ppm	ASTM D5185m	1150	800	773	683
Zinc	ppm	ASTM D5185m	1270	1062	982	995
Sulfur	ppm	ASTM D5185m	2060	2941	2641	2747
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	6	7	8
Sodium	ppm	ASTM D5185m		10	8	4
Potassium	ppm	ASTM D5185m	>20	6	11	16
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	10.8	10.9	11.7
Sulfation	Abs/.1mm	*ASTM D7415	>30	21.5	21.8	23.9
FLUID DEGRAD	DATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	18.2	19.1	20.2
Base Number (BN)	mg KOH/g	ASTM D2896	9.8	5.1	5.1	4.1



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG	
Free Water	scalar	*Visual	20.1	NEG	NEG	NEG	
FLUID PROPE	RTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	15.4	15.0	14.9	15.2	
GRAPHS							
Ferrous Alloys							
iron							
5 - nickel							
		~					
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		4*	Thusdass				
Jun 15/23 Sep 14/23	Vov22/23	Apr3/24 -	Jun25/24				
,,	_	4	ηη				
Non-ferrous Meta	s						
copper		1					
tin							
		1					
s							
$\langle \cdot \rangle$							
$\sim$							
And and a state of the state of	and the second s						
Jun 15/23 Sep 14/23	Vov22/23	Apr3/24	un25/24				
Jun	Novi	Ap	Jun				
Viscosity @ 100°C	2			Base Number			
		1	10.0	Base			
- Abnormal							
			(B/HO				
Base			9 6.0				
Base			0.0 0.0 Base Number 0.0 0.0 0.0 0.0				
			4.0			1	
Abnormal			²⁶ 2.0				
-							
	23	24		23	23	- 24 -	
Jun 15/23 Sep 14/23	Nov22/23	Apr3/24	Jun25/24	Jun 15/23 Sep 14/23	Nov22/23	Apr3/24	
т ö	N		ŗ	r š	N	-	
loarCheak USA 50	1 Madia-		NC 07510		vironmental - 856	- Houston Com	
/earCheck USA - 50 FL0121750	Recei		7 Jun 2024			ighway 6 Sou	
6222185	Teste		3 Jun 2024		Houston, T		
1100382	Diagr	iosed : 28	3 Jun 2024 - Don Baldridge US 7708				
LEET		Contact: Apolina					



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ŝ

Laboratory

Sample No.

Lab Number Unique Number

> Submitted By: Apolinar Zacarias Page 2 of 2

pzacariascano@gflenv.com

T:

F: