

OIL ANALYSIS REPORT

Area (46510R) {UNASSIGNED} 729102 Component

Diesel Engine

PETRO CANADA DURON SHP 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.




SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0119876	GFL0103545	GFL0103587
Sample Date		Client Info		24 Jun 2024	27 Feb 2024	13 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		480	540	595
Oil Changed		Client Info		N/A	Changed	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Fuel		WC Method	>3.0	<1.0	<1.0	<1.0
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>75	39	17	7
Chromium	ppm	ASTM D5185m	>5	1	<1	<1
Nickel	ppm	ASTM D5185m	>4	1	0	0
Titanium	ppm		>2	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum Lead	ppm	ASTM D5185m ASTM D5185m	>15	4		
	ppm		>25	0	0	<1
Copper	ppm		>100	3	2	1
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		<1 0	<1 0	<1 0
Cadmium	ppm	ASTM D5185m			()	0
	pp			Ū	-	-
ADDITIVES	66	method	limit/base	current	history1	history2
	ppm		limit/base 0	current 4	history1 <1	history2 <1
ADDITIVES Boron Barium		method ASTM D5185m		current	history1 <1 0	history2 <1 0
ADDITIVES Boron Barium Molybdenum	ppm	method ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60	current 4 0 64	history1 <1 0 63	history2 <1 0 60
ADDITIVES Boron Barium	ppm ppm	method ASTM D5185m ASTM D5185m	0 0 60 0	current 4 0	history1 <1 0 63 <1	history2 <1 0 60 0
ADDITIVES Boron Barium Molybdenum	ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010	current 4 0 64	history1 <1 0 63 <1 959	history2 <1 0 60 0 980
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0	Current 4 0 64 1 1067 1163	history1 <1 0 63 <1	history2 <1 0 60 0 980 1017
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150	Current 4 0 64 1 1067 1163 1129	history1 <1 0 63 <1 959 1087 976	history2 <1 0 60 0 980 1017 1016
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150 1270	Current 4 0 64 1 1067 1163 1129 1419	history1 <1 0 63 <1 959 1087 976 1208	history2 <1 0 60 0 980 1017 1016 1284
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150 1270 2060	Current 4 0 64 1 1067 1163 1129	history1 <1 0 63 <1 959 1087 976	<1 0 60 0 980 1017 1016 1284 3176
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN	ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150 1270	Current 4 0 64 1 1067 1163 1129 1419 3804 Current	history1 <1 0 63 <1 959 1087 976 1208	<1 0 60 0 980 1017 1016 1284 3176 history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150 1270 2060	Current 4 0 64 1 1067 1163 1129 1419 3804 Current 7	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4	<1 0 60 0 980 1017 1016 1284 3176
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 00 00 1010 1070 1150 1270 2060	Current 4 0 64 1 1067 1163 1129 1419 3804 Current	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4 2	<1 0 60 0 980 1017 1016 1284 3176 history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 00 00 1010 1070 1150 1270 2060	Current 4 0 64 1 1067 1163 1129 1419 3804 Current 7	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4	history2 <1 0 60 0 980 1017 1016 1284 3176 history2 2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	0 0 60 1010 1070 1150 1270 2060 kimit/base	current 4 0 64 1 1067 1163 1129 1419 3804 current 7 45 4	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4 2	<1 0 60 0 980 1017 1016 1284 3176 history2 2 <1
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 limit/base >25	current 4 0 64 1 1067 1163 1129 1419 3804 current 7 45 4	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4 2 <1	<1 0 60 0 980 1017 1016 1284 3176 history2 2 <1
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 Imit/base >25	current 4 0 64 1 1067 1163 1129 1419 3804 current 7 45 4 current	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4 2 <1 history1	<1 0 60 0 980 1017 1016 1284 3176 history2 2 <1 <1 <1 history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot %	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 limit/base >25 >20	current 4 0 64 1 1067 1163 1129 1419 3804 current 7 45 4 current 1.2	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4 2 <1 history1 0 0.8	<1 0 60 0 980 1017 1016 1284 3176 history2 2 <1 <1 0 history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm ppm ppm ppm ppm ppm t t t t	method ASTM D5185m ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 <i>limit/base</i> >25 >20 <i>limit/base</i> >6 >20	current 4 0 64 1 1067 1163 1129 1419 3804 current 7 45 4 current 1.2 10.2 23.5	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4 2 <1 history1 4 2 <1 history1 0.8 7.7	history2 <1 0 60 0 980 1017 1016 1284 3176 history2 2 <1 history2 0 0.6 6.3
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm t t t t	method ASTM D5185m ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 imit/base >25 imit/base >6 >20 >30	current 4 0 64 1 1067 1163 1129 1419 3804 current 7 45 4 current 1.2 10.2 23.5	history1 <1 0 63 <1 959 1087 976 1208 3009 history1 4 2 <1 0.8 7.7 19.6	<1 0 60 0 980 1017 1016 1284 3176 history2 2 <1 <1 0.6 6.3 19.2




OIL ANALYSIS REPORT





VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.4	13.9	13.8	14.3
GRAPHS						



Certificate 12367 To discuss - Denotes Statements

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: GFL958 [WUSCAR] 06222997 (Generated: 06/28/2024 15:36:25) Rev: 1

Submitted By: Also GFL958,958A, 958B - Bryan Link

T:

F: