


# **OIL ANALYSIS REPORT**

# **INJECT B ROOM [99079035]**

KR-GR-003240 - INCLINE AUGER B (SOUTH) (S/N INJECT B - 11513041)

# Gearbox

PETRO CANADA 220 (6 QTS)



## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. ( Customer Sample Comment: 99079035)

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


### Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0117999	PCA0055962	PCA0088773
Sample Date		Client Info		02 Jul 2024	16 Apr 2024	22 Jan 2024
	hrs	Client Info		0	0	0
	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				MARGINAL	ABNORMAL	NORMAL
WEAR METALS	3	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	<1	2	0
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	0	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
_	ppm	ASTM D5185m	>200	0	<1	0
	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		0	<1	0
	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		38	<1	35
Barium	ppm	ASTM D5185m		4	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	0
	ppm	ASTM D5185m		<1	<1	<1
	ppm	ASTM D5185m		5	1	0
Calcium	ppm	ASTM D5185m		1440	47	1092
Phosphorus	ppm	ASTM D5185m		379	276	340
Zinc	ppm	ASTM D5185m		5	37	3
Sulfur	ppm	ASTM D5185m		15412	12540	12248
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	1	1	1
	ppm	ASTM D5185m		8	<1	8
_	ppm	ASTM D5185m	>20	<1	<1	0
	%	ASTM D6304		0.050		
	ppm	ASTM D6304	>2000	500		
FLUID CLEANLI	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1888	<b>△</b> 95909	
Particles >6μm		ASTM D7647	>2500	1028	<u>△</u> 20215	
Particles >14µm		ASTM D7647	>640	175	610	
Particles >21µm		ASTM D7647	>160	59	120	
Particles >38µm		ASTM D7647	>40	9	5	
Particles >71µm		ASTM D7647	>10	1	1	
Oil Cleanliness		ISO 4406 (c)	>20/18/16	18/17/15	<u>24/22/16</u>	
FLUID DEGRADA	ATION	` '	limit/base	current	history1	history2
	mg KOH/g	ASTM D8045		0.41	0.40	
				÷	0.10	



# **OIL ANALYSIS REPORT**







Certificate 12367

Report Id: KRAKIR [WUSCAR] 06228498 (Generated: 07/10/2024 11:00:09) Rev: 1

Sample No.

: PCA0117999 : 06228498 Lab Number Unique Number : 11111991

Received : 05 Jul 2024

**Tested** : 10 Jul 2024 Diagnosed

: 10 Jul 2024 - Jonathan Hester

2504 INDUSTRIAL DR KIRKSVILLE, MO US 63501

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

wallace.ward@kraftheinzcompany.com T: (660)627-1031 F: (660)627-5887

Contact: WALLACE WARD

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Submitted By: DAVID ROBINSON