


OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area

GRIND ROOM [99062848]

Machine Id

KR-GR-002930 - GRINDER A1 (EAST) (S/N GRIND A - 11513021)

Component

Gearbox

Fluid

GEAR OIL ISO 220 (6 QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. (Customer Sample Comment: 99062848)

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

Viscosity of sample indicates oil is within ISO 460 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0118981	PCA0120383	PCA0088770
Sample Date	Client Info	02 Jul 2024	21 Apr 2024	11 Jan 2024
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	Not Chngd	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >200	0	4	5
Chromium	ppm ASTM D5185m >15	0	0	<1
Nickel	ppm ASTM D5185m >15	0	0	0
Titanium	ppm ASTM D5185m	0	<1	0
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >25	0	0	2
Lead	ppm ASTM D5185m >100	0	0	0
Copper	ppm ASTM D5185m >200	8	<1	<1
Tin	ppm ASTM D5185m >25	<1	0	0
Vanadium	ppm ASTM D5185m	0	<1	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 50	0	0	<1
Barium	ppm ASTM D5185m 15	0	0	0
Molybdenum	ppm ASTM D5185m 15	0	0	<1
Manganese	ppm ASTM D5185m	<1	0	0
Magnesium	ppm ASTM D5185m 50	0	<1	0
Calcium	ppm ASTM D5185m 50	0	<1	<1
Phosphorus	ppm ASTM D5185m 350	493	413	553
Zinc	ppm ASTM D5185m 100	1	0	0
Sulfur	ppm ASTM D5185m 12500	800	1196	1323

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	2	3	2
Sodium	ppm ASTM D5185m	0	0	0
Potassium	ppm ASTM D5185m >20	<1	0	<1



FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	---	▲ 63078	---
Particles >6µm	ASTM D7647 >2500	---	▲ 19013	---
Particles >14µm	ASTM D7647 >640	---	▲ 1584	---
Particles >21µm	ASTM D7647 >160	---	▲ 471	---
Particles >38µm	ASTM D7647 >40	---	35	---
Particles >71µm	ASTM D7647 >10	---	2	---
Oil Cleanliness	ISO 4406 (c) >20/18/16	---	▲ 23/21/18	---

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 0.85	0.28	0.57	---


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220 ● 428.8	223	196

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0118981 **Received** : 05 Jul 2024
Lab Number : 06228500 **Tested** : 10 Jul 2024
Unique Number : 11111993 **Diagnosed** : 10 Jul 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: PrtCount)

KraftHeinz - Kirksville - Plant 8333 PCA
 2504 INDUSTRIAL DR
 KIRKSVILLE, MO
 US 63501
 Contact: WALLACE WARD
 wallace.ward@kraftheinzcompany.com
 T: (660)627-1031
 F: (660)627-5887

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)