


## **OIL ANALYSIS REPORT**

SAMPLE INFORMATION method

Sample Rating Trend

limit/base



history1

current

history2

RC-5 Component Reciprocating Compressor

### CHEVRON REFRIGERATION OIL WF 68 (--- GAL)

#### DIAGNOSIS

Machine Id

#### A Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil. The water content is negligible.

#### Fluid Condition


The oil viscosity is higher than normal. The AN level is acceptable for this fluid.


		mothod		ourient	Thotory	Thotory 2
Sample Number		Client Info		PCA0125477	PCA0115277	PCA0106628
Sample Date		Client Info		03 Jul 2024	23 Feb 2024	09 Oct 2023
Machine Age	hrs	Client Info		32884	30247	27960
Oil Age	hrs	Client Info		8001	5316	3031
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				ABNORMAL	ATTENTION	ATTENTION
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	0	0	0
Tin	ppm	ASTM D5185m	>15	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	0	2
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		230	183	170
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.1	0.001	0.00	0.001
ppm Water	ppm	ASTM D6304	>1000	11	0	10.7
FLUID CLEAN	LINESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	<u> </u>	510	1813
Particles >6µm		ASTM D7647	>320	<u> </u>	97	<b>388</b>
Particles >14µm		ASTM D7647	>40	<mark>/</mark> 60	6	28
Particles >21µm		ASTM D7647	>10	8	1	7
Particles >38µm		ASTM D7647	>3	0	0	1
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>18/15/12	<b>A</b> 20/18/13	16/14/10	18/16/12
FLUID DEGRA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.014	0.013	0.015


Contact/Location: Cindy Scofield - KRAWAL Page 1 of 2





# **OIL ANALYSIS REPORT**















Bottom





To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: KRAWAL [WUSCAR] 06235025 (Generated: 07/15/2024 15:08:51) Rev: 1

Laboratory

Contact/Location: Cindy Scofield - KRAWAL

Contact: Cindy Scofield

F: (607)865-8863

cindy.scofield@kraft.com T: (607)865-2330