


OIL ANALYSIS REPORT

Pickle Line [Pickle Line] 530005-SQUARING SHEAR

Gearbox

PETRO CANADA ENDURATEX EP 220 (--- GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

GAL)		May2021 Ja	an 2022 Jul 2022 Oct	2022 Apr2023 Oct2023	Apr2024	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0129251	PCA0117634	PCA0112990
Sample Date		Client Info		14 Jul 2024	08 Apr 2024	14 Feb 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METAL	.S	method	limit/base	current	history1	history2
PQ		ASTM D8184		19	16	6
Iron	ppm	ASTM D5185m	>200	5	<1	4
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	0	0	<1
Tin	ppm	ASTM D5185m	>25	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	60	32	32	33
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0	0	<1	0
Magnesium	ppm	ASTM D5185m	0	2	0	0
Calcium	ppm	ASTM D5185m		10	3	5
Phosphorus	ppm	ASTM D5185m	270	234	233	224
Zinc	ppm	ASTM D5185m	0	6	0	0
Sulfur	ppm	ASTM D5185m	11200	11266	12212	9690
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	4	4	4
Sodium	ppm	ASTM D5185m		2	1	<1
Potassium	ppm	ASTM D5185m	>20	0	0	0
FLUID DEGRAI	DATION	method	limit/base	current	history1	history2
A : 1 N	1/011/	4 OT1 4 D00 45	0.40	0.00	0.44	0.0=

0.38

Acid Number (AN)


mg KOH/g ASTM D8045 0.40


0.41


0.37



OIL ANALYSIS REPORT








VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROP	ERHES	method			history1	history2
Visc @ 40°C	cSt	ASTM D445	220	231	230	231

SAMPLE IMAGES	method
---------------	--------

Color

Bottom







Certificate 12367

Sample No.

Laboratory Lab Number : 06236192 Unique Number : 11125026

: PCA0129251

Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 15 Jul 2024

Tested : 16 Jul 2024 Diagnosed : 16 Jul 2024 - Wes Davis

SDI - Steel DynamicsInc. - Heartland

455 West Industrial Drive Terre Haute, IN US 47802

Contact: BRAD ELLIS brad.ellis@steeldynamics.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: