


# OIL ANALYSIS REPORT

## Sample Rating Trend



**NORMAL**



Area  
**PONCA CITY**  
 Machine Id  
**Unit 02 DB130102E**  
 Component  
**Natural Gas Engine**  
 Fluid  
**PETRO CANADA DURON MONOGRADE HD 40W (350 GAL)**

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

#### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PCA0100345</b>	PCA0100344	PCA0100343
Sample Date	Client Info		<b>02 Jul 2024</b>	03 Jun 2024	01 May 2024
Machine Age	hrs	Client Info	<b>4172</b>	3610	2969
Oil Age	hrs	Client Info	<b>4172</b>	3610	2969
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

### CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>4</b>	4	5
Chromium	ppm	ASTM D5185m >4	<b>&lt;1</b>	0	<1
Nickel	ppm	ASTM D5185m >2	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m >3	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >9	<b>3</b>	2	1
Lead	ppm	ASTM D5185m >30	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >35	<b>&lt;1</b>	1	<1
Tin	ppm	ASTM D5185m >4	<b>0</b>	<1	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>2</b>	2	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>10</b>	<1	1
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	0
Magnesium	ppm	ASTM D5185m	<b>979</b>	948	932
Calcium	ppm	ASTM D5185m	<b>1123</b>	1098	1096
Phosphorus	ppm	ASTM D5185m	<b>1190</b>	1282	1277
Zinc	ppm	ASTM D5185m	<b>1426</b>	1404	1402
Sulfur	ppm	ASTM D5185m	<b>3266</b>	4025	3653

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	<b>3</b>	2	4
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	3	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	2	2
Fuel	%	ASTM D3524 >4.0	<b>1.4</b>	1.2	1.2






### INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624 >20	<b>4.2</b>	4.0	3.9
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>13.5</b>	12.9	13.1

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>7.2</b>	6.9	7.0
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>1.54</b>	1.76	1.76
Base Number (BN)	mg KOH/g	ASTM D2896 8.5	<b>8.71</b>	8.52	8.45









# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	13.6	13.7

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : PCA0100345

**Lab Number** : 06237049

**Unique Number** : 11125883

**Test Package** : MOB 2 ( Additional Tests: FuelDilution, PercentFuel )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**Received** : 15 Jul 2024

**Tested** : 17 Jul 2024

**Diagnosed** : 17 Jul 2024 - Sean Felton

**Magellan Midstream LP - Ponca City**

3990 South Union Street

Ponca City, OK

US 74601

Contact: Jake Daniel

Jacob.Daniel@magellanlp.com

T:

F: