


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
Abner Gap 1
 Component
Natural Gas Engine
 Fluid

CITGO PACEMAKER GAS ENGIN 1700 SERIES 40W (50 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PCA0117225	PCA0117227	PCA0111855
Sample Date	Client Info		08 Jul 2024	03 May 2024	03 Apr 2024
Machine Age	hrs	Client Info	142046	140475	139792
Oil Age	hrs	Client Info	142046	0	0
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	5	6	5
Chromium	ppm	ASTM D5185m	>4	0	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	<1	<1
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	2	<1	1
Lead	ppm	ASTM D5185m	>30	3	5	4
Copper	ppm	ASTM D5185m	>35	2	3	2
Tin	ppm	ASTM D5185m	>4	0	1	2
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		0	<1	<1

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		2	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		2	2	2
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		8	7	7
Calcium	ppm	ASTM D5185m		1810	1659	1645
Phosphorus	ppm	ASTM D5185m		351	376	357
Zinc	ppm	ASTM D5185m		488	489	453
Sulfur	ppm	ASTM D5185m		3140	3186	2775

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>+100	2	3	2
Sodium	ppm	ASTM D5185m		3	0	0
Potassium	ppm	ASTM D5185m	>20	3	5	3
Fuel	%	ASTM D3524	>4.0	0.1	0.1	0.2






INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	6.7	6.1	5.8
Sulfation	Abs/.1mm	*ASTM D7415	>30	20.8	20.0	19.7

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	17.1	15.9	15.1
Acid Number (AN)	mg KOH/g	ASTM D8045		1.64	1.45	1.32
Base Number (BN)	mg KOH/g	ASTM D2896		3.37	3.41	3.08









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.6	14.5	14.3

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : PCA0117225

Lab Number : 06237976

Unique Number : 11126810

Test Package : MOB 2 (Additional Tests : FuelDilution, PercentFuel)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ENERVEST OPERATING - ABNER GAP

7556 SANDLICK ROAD

BEE, VA

US 24217

Contact: Service Manager

T:

F: