


# OIL ANALYSIS REPORT

**Sample Rating Trend**


Machine Id

**6**  
Component  
**Natural Gas Engine**  
Fluid  
**PETRO CANADA SENTRON LD 3000 (--- GAL)**

## DIAGNOSIS

**Recommendation**

Resample at the next service interval to monitor. Please specify the component make and model with your next sample.

**Wear**

All component wear rates are normal.

**Contamination**

Tests indicate that there is no fuel present in the oil. There is no indication of any contamination in the oil.

**Fluid Condition**

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PCA0117243</b>	PCA0117269	PCA0112041
Sample Date	Client Info		<b>08 Jul 2024</b>	03 Jun 2024	02 May 2024
Machine Age	hrs	Client Info	<b>150139</b>	149306	148552
Oil Age	hrs	Client Info	<b>623</b>	6846	6092
Oil Changed		Client Info	<b>Changed</b>	Not Changd	Not Changd
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>4</b>	6	5
Chromium	ppm	ASTM D5185m >4	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m >2	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m >3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >9	<b>1</b>	2	<1
Lead	ppm	ASTM D5185m >30	<b>0</b>	3	1
Copper	ppm	ASTM D5185m >35	<b>6</b>	5	1
Tin	ppm	ASTM D5185m >4	<b>0</b>	1	1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 5	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 1	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 2	<b>3</b>	4	2
Manganese	ppm	ASTM D5185m 1	<b>&lt;1</b>	2	<1
Magnesium	ppm	ASTM D5185m 5	<b>8</b>	11	9
Calcium	ppm	ASTM D5185m 1220	<b>1518</b>	1541	1471
Phosphorus	ppm	ASTM D5185m 298	<b>310</b>	326	332
Zinc	ppm	ASTM D5185m 350	<b>391</b>	417	405
Sulfur	ppm	ASTM D5185m 1995	<b>2844</b>	2978	2924

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	<b>1</b>	3	3
Sodium	ppm	ASTM D5185m	<b>2</b>	2	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	5	2
Fuel	%	ASTM D3524 >4.0	<b>0.0</b>	0.2	0.0






## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624 >20	<b>5.1</b>	5.1	5.0
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>16.6</b>	16.5	16.5

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>9.5</b>	9.7	9.9
Acid Number (AN)	mg KOH/g	ASTM D8045 0.86	<b>0.94</b>	0.90	0.91
Base Number (BN)	mg KOH/g	ASTM D2896 3.9	<b>2.96</b>	3.51	3.35









# OIL ANALYSIS REPORT



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.7	13.7	13.6

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : PCA0117243

**Lab Number** : 06237978

**Unique Number** : 11126812

**Test Package** : MOB 2 ( Additional Tests : FuelDilution, PercentFuel )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**Received** : 16 Jul 2024

**Tested** : 17 Jul 2024

**Diagnosed** : 17 Jul 2024 - Wes Davis

**ENERVEST OPERATING - HAYSI A**

1242 WEST WIND ROAD

HAYSI, VA

US 24256

Contact: CHARLES GREGORY

cgregory@usacompression.com

T:

F: