

Machine Id  
**TUNDISH TURNER**  
 Component  
**Hydraulic System**  
 Fluid  
**KOST ACHIEVAL FRH 46 (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

### Fluid Condition

The pH level of this fluid is within the acceptable limits at 9.0. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PCA0107875</b>	PCA0107868	PCA0107866
Sample Date	Client Info		<b>11 Jul 2024</b>	04 Apr 2024	19 Jan 2024
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	90
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ATTENTION</b>	ATTENTION	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>0</b>	2	0
Chromium	ppm	ASTM D5185m >20	<b>0</b>	1	0
Nickel	ppm	ASTM D5185m >20	<b>&lt;1</b>	1	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >20	<b>0</b>	11	<1
Lead	ppm	ASTM D5185m >20	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Tin	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	2	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	<1	1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	1	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185m	<b>0</b>	<1	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>1</b>	<1	<1
Calcium	ppm	ASTM D5185m	<b>0</b>	3	2
Phosphorus	ppm	ASTM D5185m	<b>2</b>	9	3
Zinc	ppm	ASTM D5185m	<b>0</b>	5	8
Sulfur	ppm	ASTM D5185m	<b>1</b>	0	20

## CONTAMINANTS


	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>&lt;1</b>	3	<1
Sodium	ppm	ASTM D5185m	<b>1</b>	37	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	6	<1
Water	%	ASTM D6304 >0.05	<b>41.2</b>	40.6	36.9
ppm Water	ppm	ASTM D6304 >500	<b>412000</b>	406000	369000

## FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>2018</b>	3028	▲ 15607
Particles >6µm	ASTM D7647	>1300	<b>1099</b>	● 1649	▲ 8502
Particles >14µm	ASTM D7647	>160	● <b>187</b>	● 281	▲ 1447
Particles >21µm	ASTM D7647	>40	● <b>63</b>	● 95	▲ 487
Particles >38µm	ASTM D7647	>10	<b>10</b>	● 15	▲ 75
Particles >71µm	ASTM D7647	>3	<b>1</b>	1	▲ 8
Oil Cleanliness	ISO 4406 (c)	>19/17/14	● <b>18/17/15</b>	● 19/18/15	▲ 21/20/18

# OIL ANALYSIS REPORT


## Particle Trend




## Water (KF)




## Water (KF)



## Viscosity @ 40°C




## Acid Number



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	0.2%
Free Water	scalar	*Visual		NEG	NEG


PARAMETER	method	limit/base	current	history1	history2
pH	Scale 0-14	ASTM D1287	9.00	11.0	9.00
Visc @ 40°C	cSt	ASTM D445	43.3	45.0	44.0

## SAMPLE IMAGES




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals



### Viscosity @ 40°C



### Particle Count



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0107875 **Received** : 17 Jul 2024  
**Lab Number** : 06239202 **Tested** : 19 Jul 2024  
**Unique Number** : 11128036 **Diagnosed** : 19 Jul 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, pH )

**NUCOR STEEL KANKAKEE**  
 ONE NUCOR WAY  
 BOURBONNAIS, IL  
 US 60914  
 Contact: NATHAN DUNNILL  
 nathan.dunnill@nucor.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)