

OIL ANALYSIS REPORT

SAMPLE INFORMATION method

Sample Rating Trend



Machine Id

413075

Diesel Engine

Fluid PETRO CANADA DURON GEO LD 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORM		method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0125170	GFL0117741	GFL0103977
Sample Date		Client Info		05 Jul 2024	16 Apr 2024	31 Jan 2024
Machine Age	hrs	Client Info		4298	71871	3114
Oil Age	hrs	Client Info		0	0	3114
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
-						
CONTAMINATI	ION	method	limit/base	current	history1	history2
Fuel		WC Method	>5	<1.0	<1.0	<1.0
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>110	15	13	11
Chromium	ppm	ASTM D5185m	>4	0	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>2	<1	<1	0
Aluminum	ppm	ASTM D5185m	>25	11	12	22
Lead	ppm	ASTM D5185m	>45	0	<1	<1
Copper	ppm	ASTM D5185m	>85	<1	2	1
Tin	ppm	ASTM D5185m	>4	<1	1	<1
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method				history2
ADDITIVES Boron	ppm	method ASTM D5185m	limit/base		history1 3	history2 12
	ppm ppm	ASTM D5185m		current 2 0		
Boron Barium	ppm		50	2	3	12
Boron Barium Molybdenum	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	50 5	2 0 57	3 0	12 0
Boron Barium Molybdenum Manganese	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50	2 0 57 <1	3 0 60	12 0 54
Boron Barium Molybdenum	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0	2 0 57	3 0 60 <1	12 0 54 <1
Boron Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 50 0 560 1510	2 0 57 <1 929 1043	3 0 60 <1 888 1115	12 0 54 <1 958 1048
Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560 1510 780	2 0 57 <1 929	3 0 60 <1 888	12 0 54 <1 958
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 50 0 560 1510	2 0 57 <1 929 1043 1051	3 0 60 <1 888 1115 1085	12 0 54 <1 958 1048 1067
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560 1510 780 870	2 0 57 <1 929 1043 1051 1261	3 0 60 <1 888 1115 1085 1237 3200	12 0 54 <1 958 1048 1067 1228 2759
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560 1510 780 870 2040	2 0 57 <1 929 1043 1051 1261 3494	3 0 60 <1 888 1115 1085 1237	12 0 54 <1 958 1048 1067 1228
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon	ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m method	50 5 50 0 560 1510 780 870 2040	2 0 57 <1 929 1043 1051 1261 3494 current 4	3 0 60 <1 888 1115 1085 1237 3200 history1 5	12 0 54 <1 958 1048 1067 1228 2759 history2 4
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium	ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560 1510 780 870 2040 limit/base >30	2 0 57 <1 929 1043 1051 1261 3494 current 4 2	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0	12 0 54 <1 958 1048 1067 1228 2759 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium	ppm	ASTM D5185m ASTM D5185m	50 5 50 0 560 1510 780 870 2040 limit/base >30	2 0 57 <1 929 1043 1051 1261 3494 current 4 2 26	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0 26	12 0 54 <1 958 1048 1067 1228 2759 history2 4 <1 52
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	50 50 560 1510 780 870 2040 Imit/base >30 20	2 0 57 <1 929 1043 1051 1261 3494 current 4 2 26 current	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0 26 history1	12 0 54 <1 958 1048 1067 1228 2759 history2 4 <1 52 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot %	ppm	ASTM D5185m ASTM D5185m	50 50 560 1510 780 870 2040 Imit/base >30 204 Imit/base >30	2 0 57 <1 929 1043 1051 1261 3494 current 4 2 26 current 0.7	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0 26 history1 0.5	12 0 54 <1 958 1048 1067 1228 2759 history2 4 <1 52 history2 0.5
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm ppm ppm ppm ppm TS ppm ppm ppm	ASTM D5185m ASTM D5185m	50 50 50 150 1510 780 870 2040 imit/base >30 220 imit/base >3 220	2 0 57 <1 929 1043 1051 1261 3494 <i>current</i> 4 2 26 <i>current</i> 0.7 9.0	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0 26 history1 0.5 8.7	12 0 54 <1 958 1048 1067 1228 2759 history2 4 <1 52 history2 0.5 8.6
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	50 50 560 1510 780 870 2040 Imit/base >30 204 Imit/base >30	2 0 57 <1 929 1043 1051 1261 3494 current 4 2 26 current 0.7	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0 26 history1 0.5	12 0 54 <1 958 1048 1067 1228 2759 history2 4 <1 52 history2 0.5
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	50 50 50 150 1510 780 870 2040 imit/base >30 220 imit/base >3 220	2 0 57 <1 929 1043 1051 1261 3494 <i>current</i> 4 2 26 <i>current</i> 0.7 9.0	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0 26 history1 0.5 8.7	12 0 54 <1 958 1048 1067 1228 2759 history2 4 <1 52 history2 0.5 8.6
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	50 50 560 1510 780 870 2040 Imit/base >30 20 Imit/base >3 20	2 0 57 <1 929 1043 1051 1261 3494 current 4 2 26 current 0.7 9.0 20.4	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0 26 history1 0.5 8.7 19.7	12 0 54 <1 958 1048 1067 1228 2759 history2 4 <1 52 history2 0.5 8.6 19.1
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm TS ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D7844 *ASTM D7624 *ASTM D7414	50 50 50 560 1510 780 870 2040 2040 2040 2040 20 20 20 20 20 20 20 20 20 20 20 20 20	2 0 57 <1 929 1043 1051 1261 3494 <i>current</i> 4 2 26 <i>current</i> 0.7 9.0 20.4 <i>current</i>	3 0 60 <1 888 1115 1085 1237 3200 history1 5 0 26 history1 0.5 8.7 19.7 history1	12 0 54 <1 958 1048 1067 1228 2759 history2 4 <1 52 history2 0.5 8.6 19.1 history2




OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.1	14.6	14.5	14.2
GRAPHS						

Ferrous Alloys



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: GFL865 [WUSCAR] 06239666 (Generated: 07/19/2024 13:25:08) Rev: 1

Certificate 12367

Submitted By: TECHNICIAN ACCOUNT

F: