



CONSTRUCTION EQUIPMENT

SAP G1 B1-22583 G030517462 - DIESEL FUEL



Sample No: VCP059107
Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)
Job No: SAP G1 B1-22583



SAMPLE INFORMATION

Sample Number	VCP059107	---	---	---
Sample Date	18 Nov 2023	---	---	---
Machine Hours	0	---	---	---
Sample Status	ABNORMAL	---	---	---

CULLEN DIESEL POWER - 695335

9300 192 ST

SURREY, BC

CA V4N 3R8

Contact: MATT GLUBIS

mjg@cullendiesel.com

T:

F:



FUEL CONDITION

Sulfur	ppm	█ 10	---	---	---
Visc @ 40°C	cSt	█ 2.1	---	---	---



CONTAMINATION

Lead	ppm	█ 0	---	---	---
Nickel	ppm	█ 0	---	---	---
Aluminum	ppm	█ 0	---	---	---
Vanadium	ppm	█ 0	---	---	---
Silicon	ppm	█ <1	---	---	---

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service.(not applicable) There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot: CULSUR


Unique No: 5685042

Signed: Kevin Marson

Report Date: 04 Dec 2023



Pensky-Martens Flash Point (°C)



GCD Spectrum

