



CONSTRUCTION EQUIPMENT

R1-22589 MTU 9510500202 - DIESEL FUEL



Sample No: VCP060391
Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)
Job No: R1-22589



SAMPLE INFORMATION

Sample Number	VCP060391	---	---	---
Sample Date	21 Nov 2023	---	---	---
Machine Hours	180	---	---	---
Sample Status	NORMAL	---	---	---

CULLEN DIESEL POWER - 695335

9300 192 ST

SURREY, BC

CA V4N 3R8

Contact: MATT GLUBIS

mjg@cullendiesel.com

T:

F:



FUEL CONDITION

Sulfur	ppm	█ 10	---	---	---
Visc @ 40°C	cSt	█ 2.3	---	---	---



CONTAMINATION

Lead	ppm	█ 0	---	---	---
Nickel	ppm	█ 0	---	---	---
Aluminum	ppm	█ 0	---	---	---
Vanadium	ppm	█ 0	---	---	---
Silicon	ppm	█ 0	---	---	---

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service.(not applicable) There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot: CULSUR


Unique No: 5685043

Signed: Kevin Marson

Report Date: 04 Dec 2023



Pensky-Martens Flash Point (°C)



GCD Spectrum

