



CONSTRUCTION EQUIPMENT

SAP G2 R1-22584 J056S3S390 - DIESEL FUEL



Sample No: VCP041283
Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)
Job No: SAP G2 R1-22584



SAMPLE INFORMATION

Sample Number	VCP041283	---	---	---
Sample Date	18 Nov 2023	---	---	---
Machine Hours	0	---	---	---
Sample Status	ABNORMAL	---	---	---

CULLEN DIESEL POWER - 695335
 9300 192 ST
 SURREY, BC
 CA V4N 3R8
 Contact: MATT GLUBIS
 mjpg@cullendiesel.com
 T:
 F:



FUEL CONDITION

Sulfur	ppm	█ 12	---	---	---
Visc @ 40°C	cSt	█ 2.3	---	---	---



CONTAMINATION

Lead	ppm	█ 0	---	---	---
Nickel	ppm	█ 0	---	---	---
Aluminum	ppm	█ 0	---	---	---
Vanadium	ppm	█ 0	---	---	---
Silicon	ppm	█ 1	---	---	---


Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service.(not applicable) There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot: CULSUR
Unique No: 5685044
Signed: Kevin Marson
Report Date: 04 Dec 2023



Pensky-Martens Flash Point (°C)



GCD Spectrum

