



CONSTRUCTION EQUIPMENT

X59044 BRODERSON IC20 7012620 - DIESEL FUEL



Sample No: VCP403794
Oil Type: NOT GIVEN
Job No: X59044



SAMPLE INFORMATION

Sample Number	VCP403794	---	---	---
Sample Date	22 Dec 2023	---	---	---
Machine Hours	0	---	---	---
Sample Status	NORMAL	---	---	---

SCOTT EQUIPMENT COMPANY LLC - Saint Rose
PO BOX 997
SAINT ROSE, LA
US 70087
Contact: DANA FOSHEE
dfoshee@scottcompanies.com
T: (504)461-0961
F: (504)461-0970



FUEL CONDITION

Sulfur	ppm	0	---	---	---
Visc @ 40°C	cSt	2.02	---	---	---



CONTAMINATION

Water	%	0.003	---	---	---
Lead	ppm	0	---	---	---
Nickel	ppm	0	---	---	---
Aluminum	ppm	2	---	---	---
Vanadium	ppm	0	---	---	---
Silicon	ppm	0	---	---	---

Diagnosis

No corrective action is recommended at this time. All metal levels are normal indicating no corrosion in the system. The water content is negligible. There is no indication of any contamination in the fuel. The condition of the fuel is acceptable for the time in service.

Depot: SCOSAI
Unique No: 10809897
Signed: Jonathan Hester
Report Date: 04 Jan 2024



CONSTRUCTION EQUIPMENT



GRAPHS

Pensky-Martens Flash Point (°C)

