



R1-22767 73315433 - DIESEL FUEL

Sample No: VPA060243

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

Sample Number		VPA060243	 	
Sample Date		12 Oct 2023	 	
Machine Hours		301	 	
Sample Status		SEVERE	 	
FUEL CONDITION				
Initial Boiling Point	°C	174	 	
10% Distill Point	°C	213	 	
20% Distill Point	°C	237	 	
30% Distill Point	°C	257	 	
40% Distill Point	°C	272	 	
50% Distill Point	°C	287	 	
60% Distill Point	°C	292	 	
70% Distill Point	°C	297	 	
80% Distill Point	°C	302	 	
90% Distill Point	°C	■318	 	
Final Boiling Point	°C	367	 	
Cetane Index		70	 	
API Gravity		43	 	
Sulfur	ppm	5	 	
Visc @ 40°C	cSt	2.8	 	
Fuel Color	text	Orang	 	
CONTAMINATION				
Water	%	■ 0.002	 	
Lead	ppm	0	 	
Nickel	ppm	0	 	
Aluminum	ppm	■0	 	
Vanadium	ppm	0	 	
Silicon	ppm	0	 	

CULLEN DIESEL POWER - 695335

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Venu lyer vgi@cullendiesel.com T: (604)455-2207 F:

Diagnosis

We advise that you check all areas where contaminants can enter the system. Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. Resample in 30-45 days to monitor this situation.{not applicable} There is a high amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible. The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 ultra-lowsulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

Depot:CULSURUnique No:5659493Signed:Kevin MarsonReport Date:23 Oct 2023

OIL ANALYSIS REPORT



GRAPHS

