## **OIL ANALYSIS REPORT**

### RD1-22309 B030471688 - DIESEL FUEL

Sample No: VPA055727

**Oil Type:** DIESEL FUEL No. 2

#### SAMPLE INFORMATION Sample Number VPA055727 Sample Date 12 Oct 2023 Machine Hours 355 Sample Status NORMAL **FUEL CONDITION** Sulfur ppm 12 Visc @ 40°C cSt 2.7 F: CONTAMINATION 0 Lead ppm Nickel ppm 0 Aluminum ppm 0 Vanadium ppm 0 Silicon ppm 0

#### **CULLEN DIESEL POWER - 695335**

VOLVO PENTA

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Venu Iyer vgi@cullendiesel.com T: (604)455-2207

#### Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service.{not applicable} There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

 Depot:
 CULSUR

 Unique No:
 5668961

 Signed:
 Kevin Marson

 Report Date:
 30 Oct 2023

# **OIL ANALYSIS REPORT**



#### GRAPHS

### Pensky-Martens Flash Point (°C) 10-8 6 4 temperature °C 2 0 -2 \_4 -6 -8 -10 0ct12/23 0ct12/23 GCD Spectrum 16,000 110% 90% 15,000 14,000 13,000 12,000 11,000 10,000 9,000 Response (pA) 8,000 7,000 6,000 5,000 4,000 3,000 2,000 1,000 0 Time (min) 12 LO. 9