# **OIL ANALYSIS REPORT**

## R1-22292 KATO LIGHT WA505497 - DIESEL FUEL

Sample No: VPA055949

Oil Type: DIESEL FUEL No. 2

## SAMPLE INFORMATION

Sample Number Sample Date Machine Hours Sample Status		VPA055949 04 Jun 2023 282 NORMAL	   	  
FUEL CONDITION				
Sulfur	ppm	∎16	 	
Visc @ 40°C	cSt	2.3	 	
CONTAMINATION				
Lead	ppm	0	 	
Nickel	ppm	0	 	
Aluminum	ppm	0	 	
Vanadium	ppm	0	 	
Silicon	ppm	4	 	

#### **CULLEN DIESEL POWER - 695335**

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Venu Iyer /gi@cullendiesel.com F: (604)455-2207

### Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service.{not applicable} There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

 Depot:
 CULSUR

 Unique No:
 5668962

 Signed:
 Kevin Marson

 Report Date:
 30 Oct 2023

Contact/Location: Venu Iyer - CULSUR



# **OIL ANALYSIS REPORT**



### GRAPHS

#### Pensky-Martens Flash Point (°C) 10-8 4 ç 2 temperature 0 -2 \_4 -6 -8 -10 Jun4/23 Jun4/23 GCD Spectrum 13,000 11030 1910 12,500 12,000 11.500 11,000 10,500 10,000 9,500 9,000 8,500 8,000 7,500 (pA) 7,000 onse 6,500 Respo 6,000 5,500 5,000 4,500 4,000 3,500 3,000 2,500 2,000 1,500 1,000 500

Time (min)

0.

0

3

LO.

9