## **OIL ANALYSIS REPORT**

## R1-22286 CATERPILLAR CCK500657 - DIESEL FUEL

Sample No:

VPA055840

Oil Type: DIESEL FUEL No. 2

### SAMPLE INFORMATION

Sample Number		VPA055840	 	
Sample Date		24 Oct 2023	 	
Machine Hours		0	 	
Sample Status		NORMAL	 	
•				
FUEL CONDITION				
Sulfur	ppm	<b>10</b>	 	
Visc @ 40°C	cSt	2.5	 	
CONTAMINATION				
Land		-0		
Lead	ppm	0	 	
Nickel	ppm	0	 	
Aluminum	ppm	0	 	
Vanadium	ppm	0	 	
Silicon	ppm	0	 	

#### **CULLEN DIESEL POWER - 695335**

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Venu Iyer vgi@cullendiesel.com T: (604)455-2207 F:

#### Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service.{not applicable} There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

 Depot:
 CULSUR

 Unique No:
 5672566

 Signed:
 Kevin Marson

 Report Date:
 14 Nov 2023

Contact/Location: Venu Iyer - CULSUR



# **OIL ANALYSIS REPORT**



#### GRAPHS

## Pensky-Martens Flash Point (°C) 10-8 4 temperature °C 2 0 -2 \_4 -6 -8 -10 0ct24/23 0ct24/23 GCD Spectrum 16,000 10% 190% 15,000 14,000 13,000 12,000 11,000 10,000 9,000 Response (pA) 8,000 7,000 6,000 5,000 4,000 3,000 2,000 1,000 Time (min) 3 5 9