



95020500993 - DIESEL FUEL

Sample No: VPA059106

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

SAMPLE INFORM	IATION			
Sample Number		VPA059106	 	
Sample Date		02 Nov 2023	 	
Machine Hours		0	 	
Sample Status		NORMAL	 	
FUEL CONDITION				
Sulfur	ppm	4	 	
Visc @ 40°C	cSt	2.3	 	
CONTAMINATIO	N			
Lead	ppm	■0	 	
Nickel	ppm	■ 0	 	
Aluminum	ppm	0	 	
Vanadium	ppm	0	 	
Silicon	ppm	■ <1	 	

CULLEN DIESEL POWER - 695335

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers mns@cullendiesel.com T: (604)888-1211 F:

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5682042Signed:Kevin MarsonReport Date:20 Nov 2023

OIL ANALYSIS REPORT



GRAPHS



