



R1-22572 MTU 344227-1-1 - DIESEL FUEL

Sample No: VPA060394

Oil Type: No.2 DIESEL FUEL (LOW-SULPHUR)

SAMPLE INFORM	MATION				
Sample Number		VPA060394			
Sample Date		14 Nov 2023			
Machine Hours		0			
Sample Status		NORMAL			
FUEL CONDITION	1				
Sulfur	ppm	1 6			
Visc @ 40°C	cSt	■2.7			
CONTAMINATION					
Lead	ppm	■0			
Nickel	ppm	■ 0			
Aluminum	ppm	0			
Vanadium	ppm	0			
Silicon	ppm	■ <1			

CULLEN DIESEL POWER - 695335

9300 192 ST SURREY, BC CA V4N 3R8 Contact: MATT GLUBIS mjg@cullendiesel.com T: F:

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot: CULSUR
Unique No: 5684240
Signed: Kevin Marson
Report Date: 29 Nov 2023

OIL ANALYSIS REPORT



GRAPHS

