



R1-22580 BLUE STAR P6855 - DIESEL FUEL

Sample No: VPA060282

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

SAMPLE INFORM	MATION			
Sample Number		VPA060282	 	
Sample Date		10 Nov 2023	 	
Machine Hours		157	 	
Sample Status		NORMAL	 	
FUEL CONDITION	ı			
Sulfur	ppm	11	 	
Visc @ 40°C	cSt	■3.1	 	
CONTAMINATIO	N			
Lead	ppm	■ 0	 	
Nickel	ppm	■ 0	 	
Aluminum	ppm	0	 	
Vanadium	ppm	0	 	
Silicon	ppm	□ 0	 	

CULLEN DIESEL POWER - 695335

9300 192 ST SURREY, BC CA V4N 3R8 Contact: MATT GLUBIS mjg@cullendiesel.com T: F:

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5694457Signed:Kevin MarsonReport Date:11 Dec 2023

OIL ANALYSIS REPORT



GRAPHS

