

OIL ANALYSIS REPORT

**VOLVO
PENTA**

R1-22573 MTU 358914-1-1-0413 - DIESEL FUEL

Sample No: VPA060395

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

SAMPLE INFORMATION

| | | | | |
|---------------|-------------|-----|-----|-----|
| Sample Number | VPA060395 | --- | --- | --- |
| Sample Date | 17 Nov 2023 | --- | --- | --- |
| Machine Hours | 110 | --- | --- | --- |
| Sample Status | NORMAL | --- | --- | --- |

FUEL CONDITION

| | | | | | |
|-------------|-----|-------|-----|-----|-----|
| Sulfur | ppm | ■ 7 | --- | --- | --- |
| Visc @ 40°C | cSt | ■ 2.5 | --- | --- | --- |

CONTAMINATION

| | | | | | |
|----------|-----|-----|-----|-----|-----|
| Lead | ppm | ■ 0 | --- | --- | --- |
| Nickel | ppm | ■ 0 | --- | --- | --- |
| Aluminum | ppm | ■ 0 | --- | --- | --- |
| Vanadium | ppm | 0 | --- | --- | --- |
| Silicon | ppm | ■ 0 | --- | --- | --- |

CULLEN DIESEL POWER - 695335

9300 192 ST

SURREY, BC

CA V4N 3R8

Contact: MATT GLUBIS

mjg@cullendiesel.com

T:

F:

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service.(not applicable) There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot: CULSUR

Unique No: 5694461

Signed: Kevin Marson


Report Date: 11 Dec 2023

OIL ANALYSIS REPORT

**VOLVO
PENTA**

GRAPHS

Pensky-Martens Flash Point (°C)



GCD Spectrum

