



RI-22570 KOHLER 291087 - DIESEL FUEL

Sample No: VPA060393

Oil Type: No.2 DIESEL FUEL (LOW-SULPHUR)

SAMPLE INFORM	MATION			
Sample Number		VPA060393	 	
Sample Date		30 Nov 2023	 	
Machine Hours		207	 	
Sample Status		ABNORMAL	 	
FUEL CONDITION	l			
Sulfur	ppm	<b>77</b>	 	
Visc @ 40°C	cSt	■2.6	 	
CONTAMINATIO	N			
Lead	ppm	<b>■</b> 0	 	
Nickel	ppm	<b>■</b> 0	 	
Aluminum	ppm	<b>0</b>	 	
Vanadium	ppm	0	 	
Silicon	ppm	<b>□</b> <1	 	

## **CULLEN DIESEL POWER - 695335**

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers mns@cullendiesel.com T: (604)888-1211 F:

## Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. Iron ppm levels are abnormal. The high metal levels indicate corrosion in the system. There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5696436Signed:Kevin MarsonReport Date:18 Dec 2023

## **OIL ANALYSIS REPORT**



GRAPHS

