OIL ANALYSIS REPORT

R1-23900 JOHN DEERE PE4045E009057 FIRE PUMP - DIESEL FUEL

Sample No: VPA058989

Oil Type: No.2 DIESEL FUEL (LOW-SULPHUR)

SAMPLE INFORMATION

Sample Number		VPA058989	 	
Sample Date		15 Feb 2024	 	
Machine Hours		0	 	
Sample Status		NORMAL	 	
FUEL CONDITION				
Sulfur	ppm	5	 	
Visc @ 40°C	cSt	2.7	 	
CONTAMINATION				
Lead	ppm	■ <1	 	
Nickel	ppm	0	 	
Aluminum	ppm	0	 	
Vanadium	ppm	0	 	
Silicon	ppm	0	 	

CULLEN DIESEL POWER - 695335

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers mns@cullendiesel.com T: (604)888-1211 F:

Diagnosis

This is a baseline read-out on the submitted sample. Please contact your representative for information regarding the proper sampling kits for your service.{not applicable} There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5737810Signed:Kevin MarsonReport Date:08 Mar 2024

Contact/Location: Michelle Sayers - CULSUR



OIL ANALYSIS REPORT



GRAPHS

Pensky-Martens Flash Point (°C)

	10	T	1																	-	 	 -							T
	8		1.																										÷
	6	ŀ																											
	4	+	i																										i T
e e	2	+	ŀ																										÷
Deratu	0	ŀ																											
femil	-2	+																											÷
	-4	+ -	ŀ																										÷
	-6	+																											ł
	-8	+																											
	-10		Ļ								_		 										_						÷
		LI LI DA	Feb 1 5/24																										Feb 15/24