



R1-23892 PE4045N034873 - DIESEL FUEL

Sample No: VPA054396

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

SAMPLE INFORMATION					
Sample Number		VPA054396			
Sample Date		07 Feb 2024			
Machine Hours		43			
Sample Status		NORMAL			
FUEL CONDITION					
Sulfur	ppm	<b>5</b>			
Visc @ 40°C	cSt	■2.3			
CONTAMINATIO	N				
Lead	ppm	<b>■</b> 0			
Nickel	ppm	<b>■</b> 0			
Aluminum	ppm	<b>0</b>			
Vanadium	ppm	0			
Silicon	ppm	<b>0</b>			

## **CULLEN DIESEL POWER - 695335**

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers mns@cullendiesel.com T: (604)888-1211 F:

## Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5746091Signed:Kevin MarsonReport Date:11 Mar 2024

## **OIL ANALYSIS REPORT**



GRAPHS

