

# OIL ANALYSIS REPORT

# VOLVO PENTA

**R1-23884 365554-1-1 - DIESEL FUEL**

**Sample No:** VPA052226

**Oil Type:** No.2 DIESEL FUEL (ULTRALOW SULPHUR)

## SAMPLE INFORMATION

|               |                    |             |     |     |
|---------------|--------------------|-------------|-----|-----|
| Sample Number | <b>VPA052226</b>   | VPA050647   | --- | --- |
| Sample Date   | <b>14 Mar 2024</b> | 06 Nov 2023 | --- | --- |
| Machine Hours | <b>283</b>         | 0           | --- | --- |
| Sample Status | <b>NORMAL</b>      | NORMAL      | --- | --- |

## FUEL CONDITION

|             |     |            |     |     |     |
|-------------|-----|------------|-----|-----|-----|
| Sulfur      | ppm | <b>9</b>   | 8   | --- | --- |
| Visc @ 40°C | cSt | <b>2.3</b> | 2.1 | --- | --- |

## CONTAMINATION

|          |     |          |    |     |     |
|----------|-----|----------|----|-----|-----|
| Lead     | ppm | <b>0</b> | 0  | --- | --- |
| Nickel   | ppm | <b>0</b> | 0  | --- | --- |
| Aluminum | ppm | <b>0</b> | 0  | --- | --- |
| Vanadium | ppm | <b>0</b> | 0  | --- | --- |
| Silicon  | ppm | <b>0</b> | <1 | --- | --- |

**CULLEN DIESEL POWER - 695335**

9300 192 ST

SURREY, BC

CA V4N 3R8

Contact: Michelle Sayers

mns@cullendiesel.com

T: (604)888-1211

F:

## Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service.(not applicable) There is no indication of any contamination in the component(unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

**Depot:** CULSUR

**Unique No:** 5760667

**Signed:** Kevin Marson

**Report Date:** 09 Apr 2024

# OIL ANALYSIS REPORT

**VOLVO  
PENTA**

## GRAPHS

