



R1-23965 12VF013919 - DIESEL FUEL

Sample No: VPA054394

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

SAMPLE INFORM	ATION			
Sample Number		VPA054394	 	
Sample Date		26 Mar 2024	 	
Machine Hours		899	 	
Sample Status		NORMAL	 	
FUEL CONDITION				
Sulfur	ppm	6	 	
Visc @ 40°C	cSt	■3.4	 	
CONTAMINATION				
Lead	ppm	0	 	
Nickel	ppm	■ 0	 	
Aluminum	ppm	0	 	
Vanadium	ppm	0	 	
Silicon	ppm	0	 	

CULLEN DIESEL POWER - 695335

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers mns@cullendiesel.com T: (604)888-1211 F:

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5761737Signed:Kevin MarsonReport Date:12 Apr 2024





GRAPHS

