



R1-24388 PE4045D977398 - DIESEL FUEL

Sample No: VPA058947

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

SAMPLE INFORM	IATION			
Sample Number		VPA058947	 	
Sample Date		09 Apr 2024	 	
Machine Hours		196	 	
Sample Status		NORMAL	 	
FUEL CONDITION				
Sulfur	ppm	<b>■</b> 3	 	
Visc @ 40°C	cSt	<b>2.2</b>	 	
CONTAMINATION	١			
Lead	ppm	<b>0</b>	 	
Nickel	ppm	■0	 	
Aluminum	ppm	<b>0</b>	 	
Vanadium	ppm	0	 	
Silicon	ppm	<b>0</b>	 	

## **CULLEN DIESEL POWER - 695335**

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers mns@cullendiesel.com T: (604)888-1211 F:

## Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5762940Signed:Kevin MarsonReport Date:18 Apr 2024

## OIL ANALYSIS REPORT



GRAPHS

