



R1-23877 95010500347 - DIESEL FUEL

Sample No: VPA052238

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

SAMPLE INFORM	MATION			
Sample Number		VPA052238	 	
Sample Date		11 Apr 2024	 	
Machine Hours		129	 	
Sample Status		NORMAL	 	
FUEL CONDITION	ı			
Sulfur	ppm	■8	 	
Visc @ 40°C	cSt	<b>2.7</b>	 	
CONTAMINATIO	N			
Lead	ppm	<b>0</b>	 	
Nickel	ppm	<b>0</b>	 	
Aluminum	ppm	<b>0</b>	 	
Vanadium	ppm	0	 	
Silicon	ppm	<b>0</b>	 	

## **CULLEN DIESEL POWER - 695335**

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers mns@cullendiesel.com T: (604)888-1211 F:

## Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5772568Signed:Kevin MarsonReport Date:25 Apr 2024

## OIL ANALYSIS REPORT



GRAPHS

