



R1-24715 K15089574 - DIESEL FUEL

Sample No: VPA053323

Oil Type: DIESEL FUEL No. 2

| SAMPLE INFORM | MATION | | | |
|----------------|--------|-------------|------|--|
| Sample Number | • | VPA053323 | | |
| Sample Date | | 15 May 2024 | | |
| Machine Hours | | 132 | | |
| Sample Status | | NORMAL | | |
| FUEL CONDITION | ١ | | | |
| Sulfur | ppm | 22 | | |
| Visc @ 40°C | cSt | 2.6 | | |
| CONTAMINATIO | N | | | |
| Lead | ppm | ■ 0 | | |
| Nickel | ppm | ■ 0 | | |
| Aluminum | ppm | 0 | | |
| Vanadium | ppm | 0 | | |
| Silicon | ppm | 0 | | |

CULLEN DIESEL POWER - 695335

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers genservice@cullendiesel.com T: (604)888-1211 F:

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5789187Signed:Kevin MarsonReport Date:10 Jun 2024

OIL ANALYSIS REPORT



GRAPHS

