



R1-25085 PE6068T569737 - DIESEL FUEL

Sample No: VPA053430

Oil Type: No.2 DIESEL FUEL (ULTRALOW SULPHUR)

| SAMPLE INFORM | MATION | | | |
|----------------|--------|-------------|------|--|
| Sample Number | | VPA053430 | | |
| Sample Date | | 05 Jun 2024 | | |
| Machine Hours | | 429 | | |
| Sample Status | | NORMAL | | |
| FUEL CONDITION | l | | | |
| Sulfur | ppm | 5 | | |
| Visc @ 40°C | cSt | ■ 2.9 | | |
| CONTAMINATIO | N | | | |
| Lead | ppm | 0 | | |
| Nickel | ppm | ■0 | | |
| Aluminum | ppm | 0 | | |
| Vanadium | ppm | 0 | | |
| Silicon | ppm | 0 | | |

CULLEN DIESEL POWER - 695335

9300 192 ST SURREY, BC CA V4N 3R8 Contact: Michelle Sayers genservice@cullendiesel.com T: (604)888-1211 F:

Diagnosis

Please contact your representative for information regarding the proper sampling kits for your service. {not applicable} There is no indication of any contamination in the component (unconfirmed). Not enough sample submitted to determine fuel condition and/or classification.

Depot:CULSURUnique No:5799090Signed:Kevin MarsonReport Date:14 Jun 2024

OIL ANALYSIS REPORT



GRAPHS

