

# OIL ANALYSIS REPORT

# VOLVO PENTA

## C-1-E POST AC VOLVO PENTA 2016125589 - AUXILIARY CIRCUIT COOLANT

**Sample No:** VPA258676

**Oil Type:** CONVENTIONAL COOLANT

### SAMPLE INFORMATION

Sample Number	<b>VPA258676</b>	VPA258674	---	---
Sample Date	<b>30 Jul 2020</b>	29 Jul 2020	---	---
Machine Hours	<b>0</b>	0	---	---
Sample Status	<b>NORMAL</b>	NORMAL	---	---

### COOLANT CONDITION

pH	Scale 0-14	<b>8.71</b>	8.65	---	---
Reserve Alkalinity	Scale 0-20	---	---	---	---
Nitrites	ppm	<b>0</b>	0	---	---
Percentage Glycol	%	<b>48</b>	49	---	---
Freezing Point	°C	<b>-24</b>	-26	---	---

### CONTAMINATION

Coolant Appearance	<b>normal</b>	normal	---	---
Coolant Color	<b>Pink</b>	Pink	---	---

### POWERSECURE INC

1609 HERITAGE COMMERCE CT  
WAKE FOREST, NC  
US 27587

Contact: C. CHESLER  
cchesler@powersecure.com

T: (919)556-3056

F:

### Diagnosis

The fluid is suitable for further service. All metal levels are normal indicating no corrosion in the cooling system. There is no indication of any contamination in the coolant. The carboxylate level of this fluid is acceptable. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.

**Depot:** VP695486

**Unique No:** 9118110

**Signed:** Doug Bogart

**Report Date:** 05 Aug 2020

# OIL ANALYSIS REPORT

## GRAPHS

