



## DENNIS WOODS 7716868 VOLVO PENTA 3102191862 - STERNDRIVE - PORT GEARBOX

Sample No: VPA036287

Oil Type: GEAR OIL SAE 75W90

SAMPLE INFORM	ATION			
Sample Number		VPA036287	VPA046265	 
Sample Date		13 Sep 2023	07 Feb 2023	 
Machine Hours		2154	2114	 
Oil Hours		0	59	 
Oil Changed		Changed	Changed	 
Sample Status		NORMAL	SEVERE	 
OIL CONDITION				
Visc @ 40°C	cSt	■94.0	□130	 
CONTAMINATION				
Water	%		7.66	 
Silicon	ppm	<b>4</b>	<b>3</b>	 
Sodium	ppm	<b>16</b>	<b>6</b> 3	 
Potassium	ppm	<b>1</b>	□29	 
WEAR METALS				
PQ		<b>■25</b>	<b>6</b> 1	 
Iron	ppm	■89	<b>4</b> 0	 
Copper	ppm	<b>2</b>	<b>2</b>	 
Lead	ppm	<b>■&lt;1</b>	<b>6</b>	 
Tin	ppm	<b>0</b>	<b>2</b>	 
Aluminum	ppm	<b>■</b> 3	<b>2</b>	 
Chromium	ppm	<b>1</b>	<b>1</b>	 
Molybdenum	ppm	<b>2</b>	<b></b>	 
Nickel	ppm	<b>2</b>	<b>2</b>	 
Titanium	ppm	<1	<1	 
Silver	ppm	0	3	 
Manganese	ppm	<b>■</b> 3	<b>1</b>	 
Vanadium	ppm	0	<1	 
ADDITIVES				
Calcium	ppm	<b>7</b>	<b>2</b> 3	 
Magnesium	ppm	■25	■30	 
Zinc	ppm	<b>44</b>	<b>■</b> 28	 
Phosphorus	ppm	<b>1363</b>	■334	 
Barium	ppm	<b>0</b>	<b>0</b>	 
Boron	ppm	<b>270</b>	□ 25	 

## Pacific Power Group - VP981534

7215 S 228th St Kent, WA US 98032 Contact: PAT RYAN pryan@pacificpowergroup.com T: (253)520-5163 F:

## Diagnosis

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

Depot:VP99031103Unique No:10662636Signed:Jonathan HesterReport Date:28 Sep 2023

## **OIL ANALYSIS REPORT**



