

OIL ANALYSIS REPORT

VOLVO PENTA

RICHARD FORTIER ONAN/CUMMINS E130508929 - GENSET

Sample No: VPA035441

Oil Type: DIESEL ENGINE OIL SAE 15W40

SAMPLE INFORMATION

Sample Number	VPA035441	VPA035697	---	---
Sample Date	24 Oct 2023	28 Oct 2022	---	---
Machine Hours	606	0	---	---
Oil Hours	8	10	---	---
Oil Changed	Not Changd	Not Changd	---	---
Sample Status	NORMAL	NORMAL	---	---

OIL CONDITION

Visc @ 100°C	cSt	█ 13.9	█ 14.0	---	---
Base Number (BN)	mg KOH/g	█ 8.3	█ 9.2	---	---
Oxidation (PA)	%	64	65	---	---

CONTAMINATION

Water	%	NEG	NEG	---	---
Soot %	%	█ 0	█ 0.1	---	---
Nitration (PA)	%	43	47	---	---
Sulfation (PA)	%	55	56	---	---
Glycol	%	NEG	NEG	---	---
Fuel	%	<1.0	<1.0	---	---
Silicon	ppm	█ 6	█ 6	---	---
Sodium	ppm	█ <1	█ 3	---	---
Potassium	ppm	█ 8	█ 7	---	---

WEAR METALS

Iron	ppm	█ 2	█ 2	---	---
Copper	ppm	█ <1	█ <1	---	---
Lead	ppm	█ 0	█ 0	---	---
Tin	ppm	█ 0	█ 0	---	---
Aluminum	ppm	█ 1	█ <1	---	---
Chromium	ppm	█ 0	█ <1	---	---
Molybdenum	ppm	█ <1	█ <1	---	---
Nickel	ppm	█ 0	█ 0	---	---
Titanium	ppm	█ <1	█ 0	---	---
Silver	ppm	█ 0	█ 1	---	---
Manganese	ppm	█ 0	█ 0	---	---
Vanadium	ppm	0	0	---	---

ADDITIVES

Calcium	ppm	█ 2009	█ 2069	---	---
Magnesium	ppm	█ 12	█ 11	---	---
Zinc	ppm	█ 1066	█ 1122	---	---
Phosphorus	ppm	█ 956	█ 942	---	---
Barium	ppm	█ 0	█ 0	---	---
Boron	ppm	█ 228	█ 218	---	---

Power Products Systems LLC

90 Bay State Road

WAKEFIELD, MA

US 01880

Contact: ERIC JELLISON

ejellison@nedda.com

T: (781)831-8924

F:

Diagnosis

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

Depot: VP153550

Unique No: 10750532

Signed: Sean Felton

Report Date: 21 Nov 2023

OIL ANALYSIS REPORT

VOLVO PENTA

GRAPHS

