



## C180324408 (S/N C1803324408) - GENSET

Sample No: VPA021869

Oil Type: DIESEL ENGINE OIL SAE 15W40

SAMPLE INFORMAT	TION			
Sample Number		VPA021869	 	
Sample Date		06 Dec 2023	 	
Machine Hours		374	 	
Oil Hours		0	 	
Oil Changed		N/A	 	
Sample Status		NORMAL	 	
		110111111111	 	
OIL CONDITION				
Visc @ 100°C	cSt	<b>13.1</b>	 	
Base Number (BN)	mg KOH/g	■8.0	 	
Oxidation (PA)	%	55	 	
` '				
CONTAMINATION				
Water	%	NEG	 	
Soot %	%	■ 0.1	 	
Nitration (PA)	%	55	 	
Sulfation (PA)	%	48	 	
Glycol	%	NEG	 	
Fuel	%	<1.0	 	
Silicon	ppm	<b>6</b>	 	
Sodium	ppm	<b>■&lt;1</b>	 	
Potassium	ppm	<b>□</b> <1	 	
WEAR METALS				
Iron	ppm	<b>2</b>	 	
Copper	ppm	<1	 	
Lead	ppm	■0	 	
Tin	ppm	<b>0</b>	 	
Aluminum	ppm	<b>1</b>	 	
Chromium	ppm	<b>0</b>	 	
Molybdenum	ppm	<b>■</b> 66	 	
Nickel	ppm	0	 	
Titanium	ppm	<b>■</b> <1	 	
Silver		<b>0</b>	 	
Manganese	ppm	■0	 	
Vanadium	ppm	0	 	
	ppm	u u		
ADDITIVES				
Calcium	ppm	<b>1821</b>	 	
Magnesium	ppm	<b>246</b>	 	
Zinc	ppm	<b>1129</b>	 	
Phosphorus	ppm	■937	 	
Barium	ppm	■0	 	
Boron	ppm	<b>136</b>	 	
	1-10			

## **ADVANCED DIESEL**

1029 INDUSTRIAL BLVD, UNIT 2 NAPLES, FL US 34104 Contact: KEITH SPICER keith\_advanceddiesel@yahoo.com T: (239)580-8731 F:

## Diagnosis

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

Depot:VPADVNAPUnique No:10780102Signed:Don BaldridgeReport Date:13 Dec 2023

## **OIL ANALYSIS REPORT**



