



POWER SECURE VOLVO PENTA 2016104766 - INDUSTRIAL - DIESEL ENGINE

Sample No: VPA034425
Oil Type: MOBIL 15W40

SAMPLE INFORMAT	LION			
Sample Number		VPA034425	 	
Sample Date		28 Dec 2023	 	
Machine Hours		209	 	
Oil Hours		15	 	
Oil Changed		Changed	 	
Sample Status		NORMAL	 	
OII CONDITION				
OIL CONDITION				
Visc @ 100°C	cSt	12.8	 	
Base Number (BN)	mg KOH/g	■9.8	 	
Oxidation (PA)	%	63	 	
CONTAMINATION				
CONTAMINATION				
Water	%	NEG	 	
Soot %	%	0	 	
Nitration (PA)	%	40	 	
Sulfation (PA)	%	54	 	
Glycol	%	NEG	 	
Fuel	%	<1.0	 	
Silicon	ppm	6	 	
Sodium	ppm	<u></u> 2	 	
Potassium	ppm	<u> </u>	 	
		_		
WEAR METALS				
Iron	ppm	■<1	 	
Copper	ppm	<u></u> 27	 	
Lead	ppm		 	
Tin	ppm	■<1	 	
Aluminum	ppm	<u> </u>	 	
Chromium	ppm	■0	 	
Molybdenum	ppm	■ 49	 	
Nickel	ppm	0	 	
Titanium	ppm	0	 	
Silver	ppm	□ 0	 	
Manganese	ppm	■ <1	 	
Vanadium	ppm	0	 	
	PP111			
ADDITIVES				
Calcium	ppm	1234	 	
Magnesium	ppm	722	 	
Zinc	ppm	■ 1027	 	
Phosphorus	ppm	■ 887	 	
Barium	ppm	■0	 	
Boron	ppm	40	 	
DOTOIT	ppiii	□ 1 0	 	

INTERSTATE POWER SYSTEMS

8200 N FAIRMOUNT ST DAVENPORT, IA US 52806 Contact: JUSTIN RITZ justin.ritz@istate.com T: (563)271-2382 F:

Diagnosis

Resample at the next service interval to monitor. Metal levels are typical for a new component breaking in. There is no indication of any contamination in the oil. The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

 Depot:
 VP1103104

 Unique No:
 10816644

 Signed:
 Sean Felton

 Report Date:
 05 Jan 2024





