



## COOPER ISLAND CIBC GEN 2 PERKINS RJ513383507398C - 2 GENSET

Sample No: VPA060444
Oil Type: {unknown}

SAMPLE INFORMAT	TION			
Sample Number		VPA060444	 	
Sample Date		08 Mar 2024	 	
Machine Hours		11883	 	
Oil Hours		0	 	
Oil Changed		Changed	 	
Sample Status		NORMAL	 	
OIL CONDITION				
Visc @ 100°C	cSt	<b>■14.3</b>	 	
Base Number (BN)	mg KOH/g	9.2	 	
Oxidation (PA)	%	78	 	
CONTAMINATION				
	0/	NEC		
Water Soot %	%	NEG ■ 0.2	 	
Nitration (PA)	%	79	 	
Sulfation (PA)	%	79 59	 	
, ,	%	NEG	 	
Glycol Fuel	%	<1.0	 	
Silicon		■ 12	 	
Sodium	ppm	<b>12</b> 19	 	
Potassium	ppm ppm	■ <1	 	
WEAR METALS	le le			
		_ 1=		
ron	ppm	<b>17</b>	 	
Copper	ppm	<b>2</b>	 	
Lead 	ppm	<b>■</b> <1	 	
Tin •	ppm	<b>1</b>	 	
Aluminum	ppm	<b>4</b>	 	
Chromium	ppm	<b>■</b> <1	 	
Molybdenum	ppm	107	 	
Nickel	ppm	<b></b>	 	
Titanium	ppm	0	 	
Silver	ppm	<b>0</b>	 	
Manganese Vanadium	ppm	<1 0	 	
	ppm	U	 	
ADDITIVES				
Calcium	ppm	1816	 	
Magnesium	ppm	1740	 	
Zinc	ppm	2122	 	
Phosphorus	ppm	1603	 	
Barium	ppm	0	 	
Boron	ppm	2	 	

## **PARTS & POWER**

PO BOX 1305498, PMB1000-00 ST THOMAS, VI US 00803 Contact: KARIM PERSAUD info@partsandpower.com T: (284)494-2830 F:

## Diagnosis

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

Depot:VP981217Unique No:10930166Signed:Don BaldridgeReport Date:20 Mar 2024

## **OIL ANALYSIS REPORT**



