

OIL ANALYSIS REPORT

VOLVO PENTA

VOLVO PENTA A284256 - PORT COOLANT

Sample No: VPA053079

Oil Type: EXTENDED LIFE COOLANT

SAMPLE INFORMATION

Sample Number	VPA053079	---	---	---
Sample Date	17 Apr 2024	---	---	---
Machine Hours	541	---	---	---
Sample Status	NORMAL	---	---	---

FDDA FT PIERCE - POWER CENTER

FORT PIERCE, FL
US

Contact: KYLE GRASER
k.graser@kirbycorp.com

T:
F:

COOLANT CONDITION

pH	Scale 0-14	■ 7.75	---	---	---
Reserve Alkalinity	Scale 0-20	---	---	---	---
Nitrites	ppm	■ 600	---	---	---
Percentage Glycol	%	■ 46.1	---	---	---
Freezing Point	°C	■ -26	---	---	---

Diagnosis

No corrective action is recommended at this time. The fluid is suitable for further service. There is no indication of any contamination in the coolant. Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

CONTAMINATION

Coolant Appearance	normal	---	---	---
Coolant Color	Orange	---	---	---

Depot: VP208659
Unique No: 10983651
Signed: Doug Bogart
Report Date: 22 Apr 2024

OIL ANALYSIS REPORT

VOLVO PENTA

GRAPHS

