



## **ONAN NOT GIVEN VPA062641 - GENSET**

Sample No: VPA062641

Oil Type: CHEVRON DELO 400 MULTIGRADE 15W40

SAMPLE INFORMAT	TION			
Sample Number		VPA062641	 	
Sample Date		04 Jun 2024	 	
Machine Hours		499	 	
Oil Hours		0	 	
Oil Changed		Changed	 	
Sample Status		NORMAL	 	
OIL CONDITION				
Visc @ 100°C	cSt	<b>12.9</b>	 	
Base Number (BN)	mg KOH/g	<b>7.9</b>	 	
Oxidation (PA)	%	47	 	
CONTAMINATION				
	%	NEG		
Water Soot %	%	NEG ■ 0.1	 	
Nitration (PA)	%	58	 	
Sulfation (PA)	%	47	 	
Glycol	%	NEG	 	
Fuel	%	<1.0	 	
Silicon	ppm	<b>■</b> 6	 	
Sodium	ppm	2	 	
Potassium	ppm	<b>3</b>	 	
WEAD METALC	' '	_		
WEAR METALS				
Iron	ppm	<b>5</b>	 	
Copper	ppm	<b>1</b>	 	
Lead	ppm	<b>■ &lt;1</b>	 	
Tin	ppm	■0	 	
Aluminum	ppm	<b>1</b>	 	
Chromium	ppm	■0	 	
Molybdenum	ppm	<1	 	
Nickel	ppm	■0	 	
Titanium	ppm	<b>0</b>	 	
Silver	ppm	<b>0</b>	 	
Manganese	ppm	<b>=</b> <1	 	
Vanadium	ppm	<1	 	
ADDITIDDA				
Calcium	ppm	<b>1408</b>	 	
Magnesium	ppm	<b>734</b>	 	
Zinc	ppm	<b>■</b> 813	 	
Phosphorus	ppm	■717	 	
Barium	ppm	<b>0</b>	 	
Boron	ppm	<b>101</b>	 	
	-			

## **North Harbor Diesel Inc**

720 30Th Street
ANACORTES, WA
US 98221
Contact: ED MCFARLIN
ed@northharbordiesel.com
T:
F:

## Diagnosis

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

Depot:VP179089Unique No:11074816Signed:Sean FeltonReport Date:14 Jun 2024

## **OIL ANALYSIS REPORT**



