



DAVID BELL KOHLER 2082039 - COOLANT

Sample No: VPA058636

Oil Type: EXTENDED LIFE COOLANT

Sample Number		VPA058636	 	
Sample Date		07 Jun 2024	 	
Machine Hours		4921	 	
Sample Status		NORMAL	 	
pH	Scale 0-14	■8.08	 	
COOLANT CONDITIO	JN			
Reserve Alkalinity	Scale 0-20		 	
Nitrites	ppm	■NT	 	
Percentage Glycol	%	45.4	 	
Freezing Point	°C	-24	 	
CONTAMINATION				
Coolant Appearance		normal	 	
Coolant Color		Red	 	

MARINE EVOLUTIONS

6831 HILL PARK DR LORTON, VA US 22079 Contact: TIM STAPLES tim@marineevolutions.com T: (703)345-0365 F:

Diagnosis

No corrective action is recommended at this time. The fluid is suitable for further service. There is no indication of any contamination in the coolant. Carboxylate test failed. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.

Depot:VP446360Unique No:11075705Signed:Angela BorellaReport Date:14 Jun 2024

OIL ANALYSIS REPORT





