



47565 KOHLER 0793910 - COOLANT

Sample No: VPA061785
Oil Type: {unknown}

Sample Number		VPA061785	 	
Sample Date		20 Jun 2024	 	
Machine Hours		980	 	
Sample Status		NORMAL	 	
H.	Scale 0-14	7.96	 	
COOLANT CONDITIO				
Reserve Alkalinity	Scale 0-20		 	
Nitrites	ppm	■ NT	 	
Percentage Glycol	%	55.9	 	
reezing Point	°C	-47	 	
CONTAMINATION				
LUN I APIINA I IUN				

INTERSTATE POWER

13015 W CUSTER AVE BUTLER, WI US 53007 Contact: DAN KRAMER DAN.KRAMER@JSTATE.COM T:

Diagnosis

F:

No corrective action is recommended at this time. The fluid is suitable for further service. There is no indication of any contamination in the coolant. Carboxylate test failed. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.

Depot:VP1103150Unique No:11090108Signed:Doug BogartReport Date:25 Jun 2024

OIL ANALYSIS REPORT





