




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
GAS TURBINE

Component
Turbine

Fluid
PETRO CANADA SUPER TURBOFLO 32 (--- LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. NOTE: RPVOT TEST RESULT is 1676 minutes.

Wear

The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system.

Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Oil Condition

The condition of oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PP	PP	PP
Sample Date	Client Info		14 Feb 2007	07 May 2004	03 Mar 2003
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	0	0	---
Chromium	ppm	ASTM D5185(m)	0	0	---
Nickel	ppm	ASTM D5185(m)	0	0	---
Titanium	ppm	ASTM D5185(m)	0	0	---
Silver	ppm	ASTM D5185(m)	0	0	---
Aluminum	ppm	ASTM D5185(m)	0	0	---
Lead	ppm	ASTM D5185(m)	<1	0	---
Copper	ppm	ASTM D5185(m)	0	0	---
Tin	ppm	ASTM D5185(m)	0	0	---
Vanadium	ppm	ASTM D5185(m)	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1	---
Barium	ppm	ASTM D5185(m)	0	0	---
Molybdenum	ppm	ASTM D5185(m)	0	0	---
Manganese	ppm	ASTM D5185(m)	0	0	---
Magnesium	ppm	ASTM D5185(m)	0	0	---
Calcium	ppm	ASTM D5185(m)	0	0	---
Phosphorus	ppm	ASTM D5185(m)	115	79	---
Zinc	ppm	ASTM D5185(m)	<1	0	---
Sulfur	ppm	ASTM D5185(m)	2	0	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1	0	---
Sodium	ppm	ASTM D5185(m)	1	<1	---
Potassium	ppm	ASTM D5185(m)	<1	0	---
Water	%	ASTM D6304*	0.001	0.001	NEG

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		1463	1580	---
Particles >6µm	ASTM D7647		346	563	---
Particles >14µm	ASTM D7647		20	59	---
Particles >21µm	ASTM D7647		7	8	---
Particles >38µm	ASTM D7647		1	2	---
Particles >71µm	ASTM D7647		0	0	---
Oil Cleanliness	ISO 4406 (c)		18/16/11	18/16/13	---


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	0.033	---




OIL ANALYSIS REPORT


foaming SEQ I/II/III




Water (KF)



Acid Number



Viscosity @ 40°C








PROPERTY	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	NEG	NEG	---
Free Water	scalar	Visual*	NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	32.6	31.5	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PP
Lab Number : 01362079
Unique Number : 2396484
Test Package : IND 3 (Additional Tests: Foaming, TAN Auto)
Received : 15 Feb 2007
Tested : 19 Feb 2007
Diagnosed :


CARDINAL POWER OF CANADA
 170 HENRY ST.
 CARDINAL, ON
 CA K0E 1E0
 Contact: Barry Mayhew
 bmayhew@capstoneinfra.com
 T: (613)657-1400
 F: (613)657-1402

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.



FERROGRAPHY REPORT

Machine Id
GAS TURBINE
 Component
Turbine
 Fluid
PETRO CANADA SUPER TURBOFLO 32 (--- LTR)




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		2.9	---	---
Small Particles		DR-Ferr*		1.9	---	---
Total Particles		DR-Ferr*		4.8	---	---
Large Particles Percentage	%	DR-Ferr*		20.8	---	---
Severity Index		DR-Ferr*		2.9	---	---

FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		1		
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*				
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*		1		
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*		1		
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				
Sand/Dirt	Scale 0-10	ASTM D7684*		1		
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*				

WEAR

The direct-reading & analytical ferroggraphic results are normal indicating no abnormal wear in the system.



This page left intentionally blank