




FUEL REPORT

Sample Rating Trend



NORMAL



Area
X - Removed Equipment

Machine Id
NO UNIT

Component
Diesel Fuel

Fluid
{not provided} (--- LTR)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Contaminants

The water content is negligible. There is no Bacteria and/or Yeast present in the sample.

Fuel Condition

Not enough sample submitted to determine fuel condition and/or classification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PP	---	---
Sample Date	Client Info			06 Apr 2010	---	---
Machine Age	hrs	Client Info		0	---	---
Sample Status				NORMAL	---	---


CONTAMINANTS		method	limit/base	current	history1	history2
Water	%	ASTM D6304*	<0.05	0.002	---	---
ppm Water	ppm	ASTM D6304*	<500	23.6	---	---

MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	ASTM D6469*	>=100000	0	---	---
Yeast	CFU/ml	ASTM D6469*	>=100000	0	---	---
Mold	Colonies	ASTM D6469*	MODER	NONE	---	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					<i>no image</i>	<i>no image</i>
Bottom					<i>no image</i>	<i>no image</i>



FUEL REPORT



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PP
Lab Number : 01600733
Unique Number : 3090605
Test Package : TEST (Additional Tests: Bacteria, KF)

Received : 07 Apr 2010
Tested : 09 Apr 2010
Diagnosed : 09 Apr 2010 - Kevin Marson

CANADIAN COAST GUARD
 CCGS GRIFFON, PO BOX 1000, 401 KING ST.W
 Prescott, ON
 CA K6V 5T3
 Contact: Laurie Bosley
 Laurie.Bosley@dfo-mpo.gc.ca

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
 F: (519)383-1994