




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
BDE - PH2 COMPRESSOR #2 (S/N 60613)

Component
Reciprocating Compressor
Fluid
COMPRO XL-S 100 (5 QTS)

DIAGNOSIS

Recommendation

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

Wear

PQ levels are abnormal. Copper and iron ppm levels are abnormal. The high ferrous density (PQ) index indicates that abnormal wear is occurring.

Contamination

There is no indication of any contamination in the component.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC863613	WC834446	WC863654
Sample Date	Client Info	02 Dec 2013	07 Aug 2012	08 May 2012
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	SEVERE	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.1	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	▲ 84	▲ 109	23
Iron	ppm ASTM D5185(m) >50	▲ 166	▲ 185	14
Chromium	ppm ASTM D5185(m) >10	5	8	<1
Nickel	ppm ASTM D5185(m)	<1	<1	0
Titanium	ppm ASTM D5185(m)	<1	0	0
Silver	ppm ASTM D5185(m)	0	<1	<1
Aluminum	ppm ASTM D5185(m) >25	<1	1	<1
Lead	ppm ASTM D5185(m) >25	4	6	2
Copper	ppm ASTM D5185(m) >50	▲ 83	▲ 95	31
Tin	ppm ASTM D5185(m) >15	<1	<1	0
Antimony	ppm ASTM D5185(m)	0	<1	0
Vanadium	ppm ASTM D5185(m)	0	0	0
Beryllium	ppm ASTM D5185(m)	0	0	0
Cadmium	ppm ASTM D5185(m)	<1	<1	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)	<1	<1	0
Barium	ppm ASTM D5185(m) 40	<1	<1	0
Molybdenum	ppm ASTM D5185(m)	0	0	0
Manganese	ppm ASTM D5185(m)	1	1	0
Magnesium	ppm ASTM D5185(m)	0	1	<1
Calcium	ppm ASTM D5185(m) 40	1	2	0
Phosphorus	ppm ASTM D5185(m) 320	282	291	328
Zinc	ppm ASTM D5185(m) 40	11	12	4
Sulfur	ppm ASTM D5185(m) 3000	1595	1981	1747
Lithium	ppm ASTM D5185(m)	<1	<1	<1

CONTAMINANTS


method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >25	4	4	<1
Sodium	ppm ASTM D5185(m)	2	<1	0
Potassium	ppm ASTM D5185(m) >20	<1	3	<1

FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974* 0.11	0.169	0.18	0.16

OIL ANALYSIS REPORT


▲ Non-ferrous Metals




▲ Ferrous Alloys




Acid Number



Viscosity @ 40°C




PQ



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	LTMOD	NONE
Debris	scalar	Visual*	NONE	NONE	LIGHT
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	100.7	102	102

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


▲ Ferrous Alloys




▲ Non-ferrous Metals




Viscosity @ 40°C



▲ PQ



Acid Number



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC863613
Lab Number : 01939077
Unique Number : 3965185
Test Package : IND 2 (Additional Tests: TAN Man)
Received : 21 Aug 2014
Tested : 22 Aug 2014
Diagnosed : 22 Aug 2014 - Kevin Marson

NEWFOUNDLAND & LABRADOR HYDRO
 BAY D'ESPOIR WHSE., 1 CAMP BOGGY RD., PO BOX 100
 MILLTOWN, BAY D'ESPOIR, NL
 CA A0H 1W0
 Contact: Matthew Lambert
 matthewlambert@nlh.nl.ca
 T: (709)882-3126
 F: (709)882-3161

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.