




PROBLEM SUMMARY

Sample Rating Trend

ISO




Area
[144269]
 Machine Id
CABG1LGBR
 Component
Bearing
 Fluid
ESSO TERESSO ISO 68 (159 LTR)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	ISO 4406 (c)	ABNORMAL	ABNORMAL	NORMAL
Particles >4µm	>10000	▲ 45973	▲ 30111	16969	
Particles >6µm	>2500	▲ 14759	▲ 8582	2017	
Particles >14µm	>160	▲ 845	▲ 415	59	
Particles >21µm	>40	▲ 166	▲ 57	11	
Oil Cleanliness	>20/18/14	▲ 23/21/17	▲ 22/20/16	21/18/13	

Customer Id: NEWSTJ
 Sample No.: WC925429
 Lab Number: 02066323
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Wes Davis +1 905-569-8600 x223
wesd@wearcheck.ca

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

28 Oct 2015 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >14µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >21µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



22 Apr 2015 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
[144269]
 Machine Id
CABG1LGBR

Component
Bearing
 Fluid
ESSO TERESSO ISO 68 (159 LTR)

DIAGNOSIS

▲ Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC925429	WC925394	WC925336
Sample Date	Client Info	12 Apr 2016	28 Oct 2015	22 Apr 2015
Machine Age	cyc	Client Info	0	0
Oil Age	cyc	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.1	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	7	8	7
Iron	ppm	ASTM D5185(m) >63	<1	<1
Chromium	ppm	ASTM D5185(m)	0	0
Nickel	ppm	ASTM D5185(m)	0	0
Titanium	ppm	ASTM D5185(m)	0	0
Silver	ppm	ASTM D5185(m)	0	0
Aluminum	ppm	ASTM D5185(m) >2	<1	<1
Lead	ppm	ASTM D5185(m) >161	2	1
Copper	ppm	ASTM D5185(m) >13	<1	<1
Tin	ppm	ASTM D5185(m) >27	0	<1
Antimony	ppm	ASTM D5185(m)	0	0
Vanadium	ppm	ASTM D5185(m)	0	0
Beryllium	ppm	ASTM D5185(m)	0	0
Cadmium	ppm	ASTM D5185(m)	0	<1

ADDITIVES






method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 4.5	0	<1
Barium	ppm	ASTM D5185(m) 0.4	0	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0
Manganese	ppm	ASTM D5185(m)	0	0
Magnesium	ppm	ASTM D5185(m) 0	0	0
Calcium	ppm	ASTM D5185(m) 0	0	<1
Phosphorus	ppm	ASTM D5185(m) 0.7	<1	<1
Zinc	ppm	ASTM D5185(m) 0	<1	<1
Sulfur	ppm	ASTM D5185(m) 1315	2165	2327
Lithium	ppm	ASTM D5185(m)	<1	<1

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >12	3	3
Sodium	ppm	ASTM D5185(m)	<1	1
Potassium	ppm	ASTM D5185(m) >20	0	0



OIL ANALYSIS REPORT



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC925429 **Received** : 18 Apr 2016
Lab Number : 02066323 **Diagnosed** : 19 Apr 2016
Unique Number : 4300632 **Diagnostician** : Wes Davis
Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.


FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 45973	▲ 30111	16969
Particles >6µm	ASTM D7647	>2500	▲ 14759	▲ 8582	2017
Particles >14µm	ASTM D7647	>160	▲ 845	▲ 415	59
Particles >21µm	ASTM D7647	>40	▲ 166	▲ 57	11
Particles >38µm	ASTM D7647	>10	4	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	▲ 23/21/17	▲ 22/20/16	21/18/13

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974*	0.02	0.09	0.07	0.04

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar Visual*	NONE	NONE	NONE	NONE
Silt	scalar Visual*	NONE	NONE	NONE	NONE
Debris	scalar Visual*	NONE	VLITE	NONE	NONE
Sand/Dirt	scalar Visual*	NONE	NONE	NONE	NONE
Appearance	scalar Visual*	NORML	NORML	NORML	NORML
Odor	scalar Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar Visual*	>0.1	NEG	NEG	NEG
Free Water	scalar Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D7279(m)	68	68.3	69.0	68.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



NEWFOUNDLAND POWER INC.
 50 DUFFY PLACE, PO BOX 8910
 ST. JOHNS, NL
 CA A1B 3P6
 Contact: Paul Martin
 pmartin@newfoundlandpower.com
 T: (709)737-2926