




# PROBLEM SUMMARY

## Sample Rating Trend

ISO




Area  
**BOF/OG SYSTEM**  
 Machine Id  
**D - O.G. Fan Lube System # 7**  
 Component  
**Tank Lube System**  
 Fluid  
**ESSO NUTO H ISO 100 (135 GAL)**



## COMPONENT CONDITION SUMMARY

### Particle Trend



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647	>5000	48747	55036	43054
Particles >6µm	ASTM D7647	>1300	9158	8762	5670
Particles >14µm	ASTM D7647	>160	394	190	91
Oil Cleanliness	ISO 4406 (c)	>19/17/14	23/20/16	23/20/15	23/20/14

Customer Id: LEWBOSC  
 Sample No.: WC22127816  
 Lab Number: 02177472  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1  
 (289)291-4641 x4641  
[Bill.Quesnel@wearcheck.com](mailto:Bill.Quesnel@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Nov 22 2017	?	We recommend you service the filters on this component.
Resample	MISSED	Nov 22 2017	?	Resample in 30-45 days to monitor this situation.
Check Breathers	MISSED	Nov 22 2017	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	MISSED	Nov 22 2017	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

17 Sep 2017 Diag: Kevin Marson



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >4µm are severely high. Particles >6µm are abnormally high. Particles >14µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



11 Aug 2017 Diag: Kevin Marson



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >4µm are severely high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



16 Jul 2017 Diag: Kevin Marson




Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >4µm are severely high. Oil Cleanliness is severe. Particles >6µm are abnormally high. Particles >14µm are notably high. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**BOF/OG SYSTEM**  
 Machine Id  
**D - O.G. Fan Lube System # 7**  
 Component  
**Tank Lube System**  
 Fluid  
**ESSO NUTO H ISO 100 (135 GAL)**

## DIAGNOSIS

### Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

### Wear

All component wear rates are normal.

### Contamination

Particles >4µm are severely high. Particles >6µm are abnormally high. Particles >14µm are abnormally high. The water content is negligible.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC22127816</b>	WC22127071	WC4924760
Sample Date	Client Info	<b>22 Oct 2017</b>	17 Sep 2017	11 Aug 2017
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	SEVERE

## WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184*	>99999	<b>8</b>	19	13
Iron	ppm	ASTM D5185(m)	>20	<b>1</b>	<1
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	0
Nickel	ppm	ASTM D5185(m)	>20	<b>0</b>	0
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0
Aluminum	ppm	ASTM D5185(m)	>20	<b>0</b>	0
Lead	ppm	ASTM D5185(m)	>20	<b>1</b>	<1
Copper	ppm	ASTM D5185(m)	>20	<b>6</b>	6
Tin	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	0
Antimony	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<b>0</b>	0
Barium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	0
Manganese	ppm	ASTM D5185(m)		<b>&lt;1</b>	0
Magnesium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1
Calcium	ppm	ASTM D5185(m)		<b>34</b>	41
Phosphorus	ppm	ASTM D5185(m)		<b>323</b>	351
Zinc	ppm	ASTM D5185(m)		<b>399</b>	418
Sulfur	ppm	ASTM D5185(m)		<b>7425</b>	7679
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1






## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1
Sodium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	<1
Water	%	ASTM D6304*	>5	<b>0.012</b>	---
ppm Water	ppm	ASTM D6304*	>50000	<b>121.8</b>	---

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>5000	<b>48747</b>	55036	43054
Particles >6µm	ASTM D7647	>1300	<b>9158</b>	8762	5670
Particles >14µm	ASTM D7647	>160	<b>394</b>	190	91
Particles >21µm	ASTM D7647	>40	<b>51</b>	21	12
Particles >38µm	ASTM D7647	>10	<b>0</b>	1	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>23/20/16</b>	23/20/15	23/20/14

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	.40	<b>0.47</b>	0.47	0.36




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	VLITE	NONE
Debris	scalar	Visual*	NONE	<b>VLITE</b>	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>5	<b>.2%</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	103.3	<b>104</b>	103	103

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**  
**Sample No.** : WC22127816 **Received** : 23 Oct 2017 2330 Regional Road #3, Door: BOSC8  
**Lab Number** : **02177472** **Diagnosed** : 25 Oct 2017 NANTICOKE, ON  
**Unique Number** : 4588575 **Diagnostician** : Bill Quesnel CA N0A 1L0  
**Test Package** : IND 2 ( Additional Tests: KF, PQ )  
 Contact: Tom Walden  
 Thomas.Walden@stelco.com  
 T: (519)587-4541  
 F: (519)587-7702

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.