




# PROBLEM SUMMARY


Area  
**1 White Oil/029 #2HTU/P Pump/401A 2 Stage HTU Charge**  
 Machine Id  
**N/A 29GP401A**  
 Component  
**Gearbox**  
 Fluid  
**PETRO CANADA ENDURATEX SYNTHETIC EP 220 (50 LTR)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	ATTENTION
Particles >6µm	ASTM D7647	>5000	▲ 68496	▲ 43153	● 5626
Particles >14µm	ASTM D7647	>640	▲ 2566	● 1276	● 370
Particles >21µm	ASTM D7647	>160	▲ 563	● 253	● 141
Oil Cleanliness	ISO 4406 (c)	>--/19/16	▲ 25/23/19	▲ 24/23/17	● 23/20/16

Customer Id: PETMIS  
 Sample No.: WC22130190  
 Lab Number: 02273719  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Jun 01 2020	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	MISSED	Jun 01 2020	?	Resample in 30-45 days to monitor this situation.
Check Breathers	MISSED	Jun 01 2020	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	MISSED	Jun 01 2020	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	MISSED	Jun 01 2020	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

ISO



### 19 Dec 2018 Diag: Bill Quesnel

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. **DISCLAIMER:** Interpretation of laboratory tests is based on sample, as received from client. Source of sample and sampling technique cannot be verified. All component wear rates are normal. Particles >6µm are severely high. Particles >6µm are severely high.. Particles >14µm are notably high. Particles >21µm are notably high. Moderate concentration of visible dirt/debris present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



ISO



### 23 Aug 2018 Diag: Wes Davis

We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



ADDITIVES



### 28 May 2018 Diag: Kevin Marson

We recommend that you change the oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >6µm are abnormally high. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The white residue present in the sample is oil additive precipitate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**1 White Oil/029 #2HTU/P Pump/401A 2 Stage HTU Charge**  
 Machine Id  
**N/A 29GP401A**  
 Component  
**Gearbox**  
 Fluid  
**PETRO CANADA ENDURATEX SYNTHETIC EP 220 (50 LTR)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

### Wear

All component wear rates are normal.

### ▲ Contamination

Particles >6µm are severely high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC22130190</b>	WC22129695	WC22129277
Sample Date	Client Info		<b>17 Mar 2019</b>	19 Dec 2018	23 Aug 2018
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	SEVERE	ATTENTION

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>200	<b>25</b>	7	15
Chromium	ppm	ASTM D5185(m)	>15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1	0
Titanium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>25	<b>&lt;1</b>	0	<1
Lead	ppm	ASTM D5185(m)	>100	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185(m)	>200	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185(m)	>25	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	<1

## ADDITIVES





	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	33	<b>25</b>	29	10
Barium	ppm	ASTM D5185(m)	5	<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	<1
Manganese	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185(m)	5	<b>&lt;1</b>	<1	2
Phosphorus	ppm	ASTM D5185(m)	437	<b>402</b>	402	403
Zinc	ppm	ASTM D5185(m)	5	<b>1</b>	1	4
Sulfur	ppm	ASTM D5185(m)	5000	<b>4837</b>	4967	5132
Lithium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>50	<b>1</b>	<1	<1
Sodium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	<1

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>162272</b>	125605	42571
Particles >6µm	ASTM D7647	>5000	<b>▲ 68496</b>	▲ 43153	● 5626
Particles >14µm	ASTM D7647	>640	<b>▲ 2566</b>	● 1276	370
Particles >21µm	ASTM D7647	>160	<b>▲ 563</b>	● 253	141
Particles >38µm	ASTM D7647	>40	<b>10</b>	5	9
Particles >71µm	ASTM D7647	>10	<b>0</b>	1	1
Oil Cleanliness	ISO 4406 (c)	>--/19/16	<b>▲ 25/23/19</b>	▲ 24/23/17	● 23/20/16




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.7	<b>0.755</b>	0.45	0.50






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>LTMOD</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>VLITE</b>	▲ MODER	VLITE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	NEG	.5%
Free Water	scalar	Visual*		<b>NEG</b>	NEG	.2%

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	223	<b>222</b>	222	221

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC22130190 **Received** : 18 Mar 2019  
**Lab Number** : **02273719** **Tested** : 19 Mar 2019  
**Unique Number** : 4836955 **Diagnosed** : 19 Mar 2019 - Wes Davis  
**Test Package** : IND 2 ( Additional Tests: TAN Man )

**Petro Canada Lubricants Inc.**  
 385 Southdown Road  
 Mississauga, ON  
 CA L5J 2Y3  
 Contact: Kyle Blezard  
 kyle.blezard@HFSinclair.com  
 T: (905)403-6768  
 F: (905)822-6025

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.